Third West Weekly Report
Shepherd, Michael
to:
Joyce Ackerman, 'Craig Barnitz (cbamitz@utah.gov)'
02/28/2012 11:32 AM
Hide Details
From: "Shepherd, Michael" <Michael.Shepherd@PacifiCorp.com>

To: Joyce Ackerman/R8/USEPA/US@EPA, "'Craig Bamitz (cbamitz@utah.gov)'" <cbamitz@utah.gov>

7 Attachments

Weekly Report 2-20 to 02-24-12.pdf Third West Weekly Log - 2012-08.pdf 230171-1.pdf 230254-1.pdf 230328-1.pdf
230398-1.pdf 230511-1.pdf

Joyce & Craig,

Attached are the reports for the week of February 20, 2012.

We had positive hits of chrysotile on Tuesday and Thursday last week.

Please let me know if you have any questions.

Thanks,

Mike Shepherd
Project Manager
Rocky Mountain Power - Major Projects
801.220.4584 Office
801.631.1310 Cell
801.220.2797 Fax
michael.shepherd@pacificorp.com

PACIFICORP

R & R ENVIRONMENTAL, INC.

3RD WEST SUBSTATION REMEDIATION PROJECT

HEALTH SAFETY MANAGER (HSM)

DAILY CHECKLIST

DATE: 2/20/12

General

☑ Work area Health and Safety Inspection

NA Review and if necessary update Activity Hazard Analyses (AHA) based on planned site activities for the day

NA Safety Planning or "Tailgate" mandatory meeting for all employees and contractors prior to commencement of any site work. Instruction, review hazards, health & safety issues and any modifications to the CSHASP

NA Site hazard and safety instruction for all first time employees, contractors or visitors

NA Complete Employee Meeting Record Form B (where applicable

NA Document required Respirator Training completion with Form H

NA Record times and numbers of dump trucks and trailers as they leave the site with contaminated material.

NA Confirm return of waste material manifest documents for each load with site manager.

NA Complete all CSHASP Forms (for applicable activities planned for that day)

- NA Illness/Injury Report Form A
- NA Site-Specific Training Record Form C
- NA Hot Work Permit Form D
- NA Trench/Evacuation Permit Form E
- NA Combined Space Entry Permit From F
- NA Exclusion zone operations are practiced as instructed.
  - NA Decontamination unit is working properly.
  - NA Workers are using decontamination unit as instructed.
  - NA Workers use personal protective equipment properly.

☑ Set air samples at cardinal compass points around exclusion zone. Check throughout the day to ensure proper operation.

☑ Observe control measures for dust and fugitive materials i.e. watering excavation sites and track out prevention.

☑ Review sign-in/sign-out log throughout and at the end of the workday.

☑ Secure the site at the end of the workday; PacifiCorp Employee

Sampling

NA Soil Confirmation sampling for any newly excavated areas

NA Stationary Air Monitoring during contaminated soil removal around the perimeter of the exclusions zone

NA Personal Breathing Zone Monitoring on personnel conducting contaminated dust and soil removal

NA Digitally photograph each sample location and at any place field sampling personnel determined necessary

NA Electronically file photo files into the on-site database

☑ Complete Field Documentation
- ☑ Field Sample Data Sheets (FSDS)
- ☑ Logbook
- NA On-site computer database

☑ Label each sample media with a unique number

☑ Seal sample(s) in zip lock plastic bags

☑ Complete and include Chain of Custody (COC) Form required for shipping of samples to appropriate laboratory

☑ Package samples for transport IAW SOP 2-1, Packaging and Shipping of Environmental Samples

☑ Review and disseminate sample results as received from the laboratories to Project Manager and other appropriate managers and employees

NA Electronically file sample reports into on-site database

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation Site
Project Safety Audit

Project: 3rd West Sub Station **Date:** 2/20/12
Location: 3rd West, 1st South, SLC **Job Number:**
Survey Conducted By: Jon Craig **Title:** IH Technician

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.59	Hazard Communication Program, List of Chemicals, Training, MSDSs.			x	
1926.500 (b) & (d) (old standard)	Guardrails on open sided floors, floor holes and runways.			x	
1926.404 (b)	Ground fault circuit interrupters or an assured equipment grounding conductor program in use.	x			
1926.451 (b)	The employer shall instruct each employee in the recognition and avoidance of unsafe conditions.			x	
1926.451 (d)	Tubular welded scaffolds shall be properly braced so that they are plumb, square and rigid; legs on plumb, adjustable, mud sills, etc. to support the maximum load; guardrails and toeboards shall be installed.			x	
1926.100 (a)	Head protection, where there is a possible danger of head injury.	x			

Standard	Title	In Compliance ☐	Out of Compliance ☐	N/A ☐	Corrective Action Taken and Date
1926.652 (a) (1)	Excavation protective systems; examination by competent person when less than 5 feet in depth.	x			
1926.20 (b) (2)	Employer responsibility to initiate and maintain safety and health programs.	x			
1926.20 (b) (1)	Employer responsibility to provide for frequent and regular inspections by designated competent persons.	x			
1926.451 (e)	Manually propelled scaffolds shall have tight planking for the full width, platforms secured, ladder or stairway provided, suitable footing, stand plumbs, wheels locked, guardrails and toeboards.			x	
1926.1052 (c) (1)	Stair rail and handrail along each unprotected edge.			x	
1926.25 (a)	Debris, scrap lumber with protruding nails, not cleared for work areas, stairs and around structures.	x			
1926.50	First aid shall be available in the absence of an infirmary, or other that is reasonably accessible; first aid supplies shall be accessible and telephone numbers posted.			x	
1926.451 (a) (13)	Scaffolding safe access not provided by ladder or equivalent.			x	
1926.651 (k) (1)	Excavations, protective systems, inspected daily by a competent person and as needed.	x			
1926.403 (b) (2)	Employer shall ensure electrical equipment is free from recognized hazards, is suitable, used in accordance with the listing, labeling or certification.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (4)	Scaffolding shall have guardrails and toeboards when more than 10 feet high and when less than 45 inches of work space.			x	
1926.405 (g) (2)	Flexible cords shall be used without splice or tap; strain relief shall be provided.			x	
1926.405 (b)	Electrical boxes, fittings shall have covers, faceplates or canopy and holes shall be smooth where cords pass through; and unused openings in cabinets/boxes shall be closed.	x			
1926.701 (b)	Reinforcing steel onto which employees could fall shall be guarded.	x			
1926.1053 (b) (1)	Portable ladder side rails extend at least 3 feet or be secured at top.			x	
1926.651 (j) (2)	Excavations shall have materials or equipment placed at least 2 feet from the edge.	x			
1926.651 (c) (2)	Excavations shall have a safe means of egress such as ladders, ramps, etc.	x			
1926.150 (c) (1)	Portable fire fighting equipment shall be provided and extinguishers shall be inspected periodically.	x			
1926.102 (a) (1)	Eye and face protection shall be provided.	x			
1926.300 (b) (2)	Guards for power tools shall be used and moving parts of equipment shall be guarded.			x	
1926.350 (a) (9)	Oxygen cylinders in storage shall be separated from fuel gas cylinders by at least 20 feet or a ½" fire resistance barrier.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.405 (a) (2) (ii) (e) & (f)	Temporary lights shall be protected from breakage, not suspended by their cords and extension cord.			x	
1926.405 (a) (2) (ii) (j)	Extension cords used with portable electric tools shall be of three wire type and designed for hard or extra hard usage.	x			
1926.105 (a)	Workplaces more than 25 feet above the ground or water shall have safety nets when ladder, safety line/belts, temporary floors, scaffolds, catch platform are not practical.			x	
1926.1051 (a)	Stairway or ladder shall be provided at all access points where there is a break in elevation of 19 inches or more.			x	
1926.451 (a) (2)	Scaffolding footing or anchorage shall be sound, rigid and capable of carrying the maximum intended load.			x	
1926.500 (c) (1) (old standard)	Wall opening shall be guarded.			x	
1926.404 (f) (7)	Electrical equipment connected by cord and plug shall be grounded except if there is an isolating transformer or the tool is double insulated.	x			
1926.556 (b) (2)	When working from an aerial lift, a full body harness and lanyard attached to the boom or basket.			x	
1926.501 (b) (1) (new standard)	Guardrails, safety nets or personal fall arrest system shall be used at 6 feet or more.			x	

Standard	Title	In Compliance ☐	Out of Compliance ☐	N/A ☐	Corrective Action Taken and Date
1926.451 (a) (14)	Scaffold planking shall extend over their end support not less than 6 inches and not more than 12 inches.			x	
1926.602 (a) (9)	Bi-directional earth moving equipment shall have audible alarms.	x			
1926.451 (a) (3)	Scaffolding shall be erected, moved, dismantled or altered under the supervision of a competent person.			x	
1926.550 (b) (2)	Cranes, crawler, truck or locomotive, shall meet the design, testing, maintenance, and operation per ANSI B30.5_1968. The most recent certification shall be on file until a new one is prepared.	x			

Comments:

CVE has both a fabrication and a line crew active on the site. The line crew is hanging steel structures. Fabricators are working on forming stems stems.

Newman was back filling around the west transformer and the vaults in the northern portion of the site. Exclusion Zone was active today around northern vaults and the west portion of the site. At mid-day, the northern section deactivated after all contaminated soil was capped with clean fill.

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

R & R ENVIRONMENTAL, INC.
ASBESTOS · LEAD · INDUSTRIAL HYGIENE

3RD WEST SUBSTATION REMEDIATION PROJECT

HEALTH SAFETY MANAGER (HSM)

DAILY CHECKLIST

DATE: 02/21/11

General

NA Work area Health and Safety Inspection

NA Review and if necessary update Activity Hazard Analyses (AHA) based on planned site activities for the day

NA Safety Planning or "Tailgate" mandatory meeting for all employees and contractors prior to commencement of any site work. Instruction, review hazards, health & safety issues and any modifications to the CSHASP

NA Site hazard and safety instruction for all first time employees, contractors or visitors

NA Complete Employee Meeting Record Form B (where applicable)

NA Document required Respirator Training completion with Form H

NA Record times and numbers of dump trucks and trailers as they leave the site with contaminated material.

NA Confirm return of waste material manifest documents for each load with site manager.

NA Complete all CSHASP Forms (for applicable activities planned for that day)

- NA Illness/Injury Report Form A
- NA Site-Specific Training Record Form C
- NA Hot Work Permit Form D
- NA Trench/Evacuation Permit Form E
- NA Combined Space Entry Permit From F
- ☑ Exclusion zone operations are practiced as instructed.
  - ☑ Decontamination unit is working properly.
  - ☑ Workers are using decontamination unit as instructed.
  - ☑ Workers use personal protective equipment properly.

☑ Set air samples at cardinal compass points around exclusion zone. Check throughout the day to ensure proper operation.
Observe control measures for dust and fugitive materials i.e. watering excavation sites and track out prevention.

☑ Review sign-in/sign-out log throughout and at the end of the workday.

☑ Secure the site at the end of the workday

Sampling

NA Soil Confirmation sampling for any newly excavated areas

☑ Stationary Air Monitoring during contaminated soil removal around the perimeter of the exclusion zone

NA Personal Breathing Zone Monitoring on personnel conducting contaminated dust and soil removal

NA Digitally photograph each sample location and at any place field sampling personnel determined necessary

- ☑ Electronically file photo files into the on-site database

- ☑ Complete Field Documentation
  - ☑ Field Sample Data Sheets (FSDS)
  - ☑ Logbook
  - ☑ On-site computer database
- ☑ Label each sample media with a unique number
- ☑ Seal sample(s) in zip lock plastic bags
- ☑ Complete and include Chain of Custody (COC) Form required for shipping of samples to appropriate laboratory
- ☑ Package samples for transport IAW SOP 2-1, Packaging and Shipping of Environmental Samples
- ☑ Review and disseminate sample results as received from the laboratories to Project Manager and other appropriate managers and employees
- ☑ Electronically file sample reports into on-site database

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation Site Project Safety Audit

Project: 3rd West Sub Station **Date:** 02/21/12

Location: 3rd West, 1st South, SLC **Job Number:**

Survey Conducted By: Justin Kargis **Title:**

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.59	Hazard Communication Program, List of Chemicals, Training, MSDSs.			x	
1926.500 (b) & (d) (old standard)	Guardrails on open sided floors, floor holes and runways.			x	
1926.404 (b)	Ground fault circuit interrupters or an assured equipment grounding conductor program in use.	x			
1926.451 (b)	The employer shall instruct each employee in the recognition and avoidance of unsafe conditions.			x	
1926.451 (d)	Tubular welded scaffolds shall be properly braced so that they are plumb, square and rigid; legs on plumb, adjustable, mud sills, etc. to support the maximum load; guardrails and toe boards shall be installed.			x	
1926.100 (a)	Head protection, where there is a possible danger of head injury.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.652 (a) (1)	Excavation protective systems; examination by competent person when less than 5 feet in depth.			x	
1926.20 (b) (2)	Employer responsibility to initiate and maintain safety and health programs.			x	
1926.20 (b) (1)	Employer responsibility to provide for frequent and regular inspections by designated competent persons.			x	
1926.451 (e)	Manually propelled scaffolds shall have tight planking for the full width, platforms secured, ladder or stairway provided, suitable footing, stand plumbs, wheels locked, guardrails and toe boards.			x	
1926.1052 (c) (1)	Stair rail and handrail along each unprotected edge.			x	
1926.25 (a)	Debris, scrap lumber with protruding nails, not cleared for work areas, stairs and around structures.			x	
1926.50	First aid shall be available in the absence of an infirmary, or other that is reasonably accessible; first aid supplies shall be accessible and telephone numbers posted.			x	
1926.451 (a) (13)	Scaffolding safe access not provided by ladder or equivalent.			x	
1926.651 (k) (1)	Excavations, protective systems, inspected daily by a competent person and as needed.			x	
1926.403 (b) (2)	Employer shall ensure electrical equipment is free from recognized hazards, is suitable, used in accordance with the listing, labeling or certification.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (4)	Scaffolding shall have guardrails and toe boards when more than 10 feet high and when less than 45 inches of work space.			x	
1926.405 (g) (2)	Flexible cords shall be used without splice or tap; strain relief shall be provided.			x	
1926.405 (b)	Electrical boxes, fittings shall have covers, faceplates or canopy and holes shall be smooth where cords pass through; and unused openings in cabinets/boxes shall be closed.	x			
1926.701 (b)	Reinforcing steel onto which employees could fall shall be guarded.			x	
1926.1053 (b) (1)	Portable ladder side rails extend at least 3 feet or be secured at top.			x	
1926.651 (j) (2)	Excavations shall have materials or equipment placed at least 2 feet from the edge.			x	
1926.651 (c) (2)	Excavations shall have a safe means of egress such as ladders, ramps, etc.	x			
1926.150 (c) (1)	Portable fire fighting equipment shall be provided and extinguishers shall be inspected periodically.			x	
1926.102 (a) (1)	Eye and face protection shall be provided.	x			
1926.300 (b) (2)	Guards for power tools shall be used and moving parts of equipment shall be guarded.	x			
1926.350 (a) (9)	Oxygen cylinders in storage shall be separated from fuel gas cylinders by at least 20 feet or a ½ fire resistance barrier.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.405 (a) (2) (ii) (e) & (f)	Temporary lights shall be protected from breakage, not suspended by their cords and extension cord.			X	
1926.405 (a) (2) (ii) (j)	Extension cords used with portable electric tools shall be of three wire type and designed for hard or extra hard usage.	x			
1926.105 (a)	Workplaces more than 25 feet above the ground or water shall have safety nets when ladder, safety line/belts, temporary floors, scaffolds, catch platform are not practical.			x	
1926.1051 (a)	Stairway or ladder shall be provided at all access points where there is a break in elevation of 19 inches or more.	x			
1926.451 (a) (2)	Scaffolding footing or anchorage shall be sound, rigid and capable of carrying the maximum intended load.	x			
1926.500 (c) (1) (old standard)	Wall opening shall be guarded.			x	
1926.404 (f) (7)	Electrical equipment connected by cord and plug shall be grounded except if there is an isolating transformer or the tool is double insulated.	x			
1926.556 (b) (2)	When working from an aerial lift, a full body harness and lanyard attached to the boom or basket.			x	
1926.501 (b) (1) (new standard)	Guardrails, safety nets or personal fall arrest system shall be used at 6 feet or more.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (14)	Scaffold planking shall extend over their end support not less than 6 inches and not more than 12 inches.	x			
1926.602 (a) (9)	Bi-directional earth moving equipment shall have audible alarms.	x			
1926.451 (a) (3)	Scaffolding shall be erected, moved, dismantled or altered under the supervision of a competent person.			x	
1926.550 (b) (2)	Cranes, crawler, truck or locomotive, shall meet the design, testing, maintenance, and operation per ANSI B30.5_1968. The most recent certification shall be on file until a new one is prepared.			x	

Comments:

Exclusion zone activated once excavations began.

Exclusion zone has been extended to include the north arm of the yard.

Newman began digging out areas for duct banks in north arm. Native soil is being moved over to the area of the old switch gear where it is held until they continue hauling off site. They also worked on setting conduit between vaults.

CVE fabricators worked on forming stems south of 2nd transformer pad.

CVE electricians continued working panel wiring in control building.

Weather was mostly sunny with highs in the low 40s. No precipitation.

PACIFICORP

R & R ENVIRONMENTAL, INC.

3RD WEST SUBSTATION REMEDIATION PROJECT

HEALTH SAFETY MANAGER (HSM)

DAILY CHECKLIST

DATE: 02/22/11

General

NA Work area Health and Safety Inspection

NA Review and if necessary update Activity Hazard Analyses (AHA) based on planned site activities for the day

NA Safety Planning or "Tailgate" mandatory meeting for all employees and contractors prior to commencement of any site work. Instruction, review hazards, health & safety issues and any modifications to the CSHASP

NA Site hazard and safety instruction for all first time employees, contractors or visitors

NA Complete Employee Meeting Record Form B (where applicable)

NA Document required Respirator Training completion with Form H

NA Record times and numbers of dump trucks and trailers as they leave the site with contaminated material.

NA Confirm return of waste material manifest documents for each load with site manager.

NA Complete all CSHASP Forms (for applicable activities planned for that day)

- NA Illness/Injury Report Form A
- NA Site-Specific Training Record Form C
- NA Hot Work Permit Form D
- NA Trench/Evacuation Permit Form E
- NA Combined Space Entry Permit From F
- ☑ Exclusion zone operations are practiced as instructed.
  - ☑ Decontamination unit is working properly.
  - ☑ Workers are using decontamination unit as instructed.
  - ☑ Workers use personal protective equipment properly.

☑ Set air samples at cardinal compass points around exclusion zone. Check throughout the day to ensure proper operation.
Observe control measures for dust and fugitive materials i.e. watering excavation sites and track out prevention.

☑ Review sign-in/sign-out log throughout and at the end of the workday.

☑ Secure the site at the end of the workday

Sampling

NA Soil Confirmation sampling for any newly excavated areas

☑ Stationary Air Monitoring during contaminated soil removal around the perimeter of the exclusion zone

NA Personal Breathing Zone Monitoring on personnel conducting contaminated dust and soil removal

NA Digitally photograph each sample location and at any place field sampling personnel determined necessary

- ☑ Electronically file photo files into the on-site database

- ☑ Complete Field Documentation
  - ☑ Field Sample Data Sheets (FSDS)
  - ☑ Logbook
  - ☑ On-site computer database
- ☑ Label each sample media with a unique number
- ☑ Seal sample(s) in zip lock plastic bags
- ☑ Complete and include Chain of Custody (COC) Form required for shipping of samples to appropriate laboratory
- ☑ Package samples for transport lAW SOP 2-1, Packaging and Shipping of Environmental Samples
- ☑ Review and disseminate sample results as received from the laboratories to Project Manager and other appropriate managers and employees
- ☑ Electronically file sample reports into on-site database

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation Site Project Safety Audit

Project: 3rd West Sub Station **Date:** 02/22/12

Location: 3rd West, 1st South, SLC **Job Number:**

Survey Conducted By: Justin Kargis **Title:**

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.59	Hazard Communication Program, List of Chemicals, Training, MSDSs.			x	
1926.500 (b) & (d) (old standard)	Guardrails on open sided floors, floor holes and runways.			x	
1926.404 (b)	Ground fault circuit interrupters or an assured equipment grounding conductor program in use.	x			
1926.451 (b)	The employer shall instruct each employee in the recognition and avoidance of unsafe conditions.			x	
1926.451 (d)	Tubular welded scaffolds shall be properly braced so that they are plumb, square and rigid; legs on plumb, adjustable, mud sills, etc. to support the maximum load; guardrails and toe boards shall be installed.			x	
1926.100 (a)	Head protection, where there is a possible danger of head injury.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.652 (a) (1)	Excavation protective systems; examination by competent person when less than 5 feet in depth.			x	
1926.20 (b) (2)	Employer responsibility to initiate and maintain safety and health programs.			x	
1926.20 (b) (1)	Employer responsibility to provide for frequent and regular inspections by designated competent persons.			x	
1926.451 (e)	Manually propelled scaffolds shall have tight planking for the full width, platforms secured, ladder or stairway provided, suitable footing, stand plumbs, wheels locked, guardrails and toe boards.			x	
1926.1052 (c) (1)	Stair rail and handrail along each unprotected edge.			x	
1926.25 (a)	Debris, scrap lumber with protruding nails, not cleared for work areas, stairs and around structures.			x	
1926.50	First aid shall be available in the absence of an infirmary, or other that is reasonably accessible; first aid supplies shall be accessible and telephone numbers posted.			x	
1926.451 (a) (13)	Scaffolding safe access not provided by ladder or equivalent.			x	
1926.651 (k) (1)	Excavations, protective systems, inspected daily by a competent person and as needed.			x	
1926.403 (b) (2)	Employer shall ensure electrical equipment is free from recognized hazards, is suitable, used in accordance with the listing, labeling or certification.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (4)	Scaffolding shall have guardrails and toe boards when more than 10 feet high and when less than 45 inches of work space.			x	
1926.405 (g) (2)	Flexible cords shall be used without splice or tap; strain relief shall be provided.			x	
1926.405 (b)	Electrical boxes, fittings shall have covers, faceplates or canopy and holes shall be smooth where cords pass through; and unused openings in cabinets/boxes shall be closed.	x			
1926.701 (b)	Reinforcing steel onto which employees could fall shall be guarded.			x	
1926.1053 (b) (1)	Portable ladder side rails extend at least 3 feet or be secured at top.			x	
1926.651 (j) (2)	Excavations shall have materials or equipment placed at least 2 feet from the edge.			x	
1926.651 (c) (2)	Excavations shall have a safe means of egress such as ladders, ramps, etc.	x			
1926.150 (c) (1)	Portable fire fighting equipment shall be provided and extinguishers shall be inspected periodically.			x	
1926.102 (a) (1)	Eye and face protection shall be provided.	x			
1926.300 (b) (2)	Guards for power tools shall be used and moving parts of equipment shall be guarded.	x			
1926.350 (a) (9)	Oxygen cylinders in storage shall be separated from fuel gas cylinders by at least 20 feet or a ½ fire resistance barrier.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.405 (a) (2) (ii) (e) & (f)	Temporary lights shall be protected from breakage, not suspended by their cords and extension cord.			X	
1926.405 (a) (2) (ii) (j)	Extension cords used with portable electric tools shall be of three wire type and designed for hard or extra hard usage.	x			
1926.105 (a)	Workplaces more than 25 feet above the ground or water shall have safety nets when ladder, safety line/belts, temporary floors, scaffolds, catch platform are not practical.			x	
1926.1051 (a)	Stairway or ladder shall be provided at all access points where there is a break in elevation of 19 inches or more.	x			
1926.451 (a) (2)	Scaffolding footing or anchorage shall be sound, rigid and capable of carrying the maximum intended load.	x			
1926.500 (c) (1) (old standard)	Wall opening shall be guarded.			x	
1926.404 (f) (7)	Electrical equipment connected by cord and plug shall be grounded except if there is an isolating transformer or the tool is double insulated.	x			
1926.556 (b) (2)	When working from an aerial lift, a full body harness and lanyard attached to the boom or basket.			x	
1926.501 (b) (1) (new standard)	Guardrails, safety nets or personal fall arrest system shall be used at 6 feet or more.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (14)	Scaffold planking shall extend over their end support not less than 6 inches and not more than 12 inches.	x			
1926.602 (a) (9)	Bi-directional earth moving equipment shall have audible alarms.	x			
1926.451 (a) (3)	Scaffolding shall be erected, moved, dismantled or altered under the supervision of a competent person.			x	
1926.550 (b) (2)	Cranes, crawler, truck or locomotive, shall meet the design, testing, maintenance, and operation per ANSI B30.5_1968. The most recent certification shall be on file until a new one is prepared.			x	

Comments:

Exclusion zone activated once excavations began.

Newman continued excavating areas for duct banks. They also delivered several loads of backfill material that were placed at the south end of the yard.

CVE fabricators continued forming stem structures.

CVE electricians continued wiring work in the control building.

CVE line crew departed site by 9:30 due to inability to mount structural steel on stem structures.

Weather was warm and mostly sunny with highs in the upper 50s. Very slight winds and no precipitation.

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

R & R ENVIRONMENTAL, INC.
ASBESTOS • LEAD • INDUSTRIAL HYGIENE

3RD WEST SUBSTATION REMEDIATION PROJECT

HEALTH SAFETY MANAGER (HSM)

DAILY CHECKLIST

DATE: 02/23/11

General

NA Work area Health and Safety Inspection

NA Review and if necessary update Activity Hazard Analyses (AHA) based on planned site activities for the day

NA Safety Planning or "Tailgate" mandatory meeting for all employees and contractors prior to commencement of any site work. Instruction, review hazards, health & safety issues and any modifications to the CSHASP

NA Site hazard and safety instruction for all first time employees, contractors or visitors

NA Complete Employee Meeting Record Form B (where applicable)

NA Document required Respirator Training completion with Form H

NA Record times and numbers of dump trucks and trailers as they leave the site with contaminated material.

NA Confirm return of waste material manifest documents for each load with site manager.

NA Complete all CSHASP Forms (for applicable activities planned for that day)

- NA Illness/Injury Report Form A
- NA Site-Specific Training Record Form C
- NA Hot Work Permit Form D
- NA Trench/Evacuation Permit Form E
- NA Combined Space Entry Permit From F
- ☑ Exclusion zone operations are practiced as instructed.
  - ☑ Decontamination unit is working properly.
  - ☑ Workers are using decontamination unit as instructed.
  - ☑ Workers use personal protective equipment properly.

☑ Set air samples at cardinal compass points around exclusion zone. Check throughout the day to ensure proper operation.
Observe control measures for dust and fugitive materials i.e. watering excavation sites and track out prevention.

☑ Review sign-in/sign-out log throughout and at the end of the workday.

☑ Secure the site at the end of the workday

Sampling

NA Soil Confirmation sampling for any newly excavated areas

☑ Stationary Air Monitoring during contaminated soil removal around the perimeter of the exclusion zone

NA Personal Breathing Zone Monitoring on personnel conducting contaminated dust and soil removal

NA Digitally photograph each sample location and at any place field sampling personnel determined necessary

- ☑ Electronically file photo files into the on-site database

- ☑ Complete Field Documentation
  - ☑ Field Sample Data Sheets (FSDS)
  - ☑ Logbook
  - ☑ On-site computer database
- ☑ Label each sample media with a unique number
- ☑ Seal sample(s) in zip lock plastic bags
- ☑ Complete and include Chain of Custody (COC) Form required for shipping of samples to appropriate laboratory
- ☑ Package samples for transport IAW SOP 2-1, Packaging and Shipping of Environmental Samples
- ☑ Review and disseminate sample results as received from the laboratories to Project Manager and other appropriate managers and employees
- ☑ Electronically file sample reports into on-site database

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation Site Project Safety Audit

Project: 3rd West Sub Station **Date:** 02/23/12

Location: 3rd West, 1st South, SLC **Job Number:**

Survey Conducted By: Justin Kargis **Title:**

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.59	Hazard Communication Program, List of Chemicals, Training, MSDSs.			x	
1926.500 (b) & (d) (old standard)	Guardrails on open sided floors, floor holes and runways.			x	
1926.404 (b)	Ground fault circuit interrupters or an assured equipment grounding conductor program in use.	x			
1926.451 (b)	The employer shall instruct each employee in the recognition and avoidance of unsafe conditions.			x	
1926.451 (d)	Tubular welded scaffolds shall be properly braced so that they are plumb, square and rigid; legs on plumb, adjustable, mud sills, etc. to support the maximum load; guardrails and toe boards shall be installed.			x	
1926.100 (a)	Head protection, where there is a possible danger of head injury.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.652 (a) (1)	Excavation protective systems; examination by competent person when less than 5 feet in depth.			x	
1926.20 (b) (2)	Employer responsibility to initiate and maintain safety and health programs.			x	
1926.20 (b) (1)	Employer responsibility to provide for frequent and regular inspections by designated competent persons.			x	
1926.451 (e)	Manually propelled scaffolds shall have tight planking for the full width, platforms secured, ladder or stairway provided, suitable footing, stand plumbs, wheels locked, guardrails and toe boards.			x	
1926.1052 (c) (1)	Stair rail and handrail along each unprotected edge.			x	
1926.25 (a)	Debris, scrap lumber with protruding nails, not cleared for work areas, stairs and around structures.			x	
1926.50	First aid shall be available in the absence of an infirmary, or other that is reasonably accessible; first aid supplies shall be accessible and telephone numbers posted.			x	
1926.451 (a) (13)	Scaffolding safe access not provided by ladder or equivalent.			x	
1926.651 (k) (1)	Excavations, protective systems, inspected daily by a competent person and as needed.			x	
1926.403 (b) (2)	Employer shall ensure electrical equipment is free from recognized hazards, is suitable, used in accordance with the listing, labeling or certification.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (4)	Scaffolding shall have guardrails and toe boards when more than 10 feet high and when less than 45 inches of work space.			x	
1926.405 (g) (2)	Flexible cords shall be used without splice or tap; strain relief shall be provided.			x	
1926.405 (b)	Electrical boxes, fittings shall have covers, faceplates or canopy and holes shall be smooth where cords pass through; and unused openings in cabinets/boxes shall be closed.	x			
1926.701 (b)	Reinforcing steel onto which employees could fall shall be guarded.			x	
1926.1053 (b) (1)	Portable ladder side rails extend at least 3 feet or be secured at top.			x	
1926.651 (j) (2)	Excavations shall have materials or equipment placed at least 2 feet from the edge.			x	
1926.651 (c) (2)	Excavations shall have a safe means of egress such as ladders, ramps, etc.	x			
1926.150 (c) (1)	Portable fire fighting equipment shall be provided and extinguishers shall be inspected periodically.			x	
1926.102 (a) (1)	Eye and face protection shall be provided.	x			
1926.300 (b) (2)	Guards for power tools shall be used and moving parts of equipment shall be guarded.	x			
1926.350 (a) (9)	Oxygen cylinders in storage shall be separated from fuel gas cylinders by at least 20 feet or a ½ fire resistance barrier.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.405 (a) (2) (ii) (e) & (f)	Temporary lights shall be protected from breakage, not suspended by their cords and extension cord.			X	
1926.405 (a) (2) (ii) (j)	Extension cords used with portable electric tools shall be of three wire type and designed for hard or extra hard usage.	x			
1926.105 (a)	Workplaces more than 25 feet above the ground or water shall have safety nets when ladder, safety line/belts, temporary floors, scaffolds, catch platform are not practical.			x	
1926.1051 (a)	Stairway or ladder shall be provided at all access points where there is a break in elevation of 19 inches or more.	x			
1926.451 (a) (2)	Scaffolding footing or anchorage shall be sound, rigid and capable of carrying the maximum intended load.	x			
1926.500 (c) (1) (old standard)	Wall opening shall be guarded.			x	
1926.404 (f) (7)	Electrical equipment connected by cord and plug shall be grounded except if there is an isolating transformer or the tool is double insulated.	x			
1926.556 (b) (2)	When working from an aerial lift, a full body harness and lanyard attached to the boom or basket.			x	
1926.501 (b) (1) (new standard)	Guardrails, safety nets or personal fall arrest system shall be used at 6 feet or more.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (14)	Scaffold planking shall extend over their end support not less than 6 inches and not more than 12 inches.	x			
1926.602 (a) (9)	Bi-directional earth moving equipment shall have audible alarms.	x			
1926.451 (a) (3)	Scaffolding shall be erected, moved, dismantled or altered under the supervision of a competent person.			x	
1926.550 (b) (2)	Cranes, crawler, truck or locomotive, shall meet the design, testing, maintenance, and operation per ANSI B30.5_1968. The most recent certification shall be on file until a new one is prepared.			x	

Comments:

Exclusion zone activated once excavations began.

EZ fencing had been blown over by winds overnight.

Newman continued excavating areas for duct banks. They also delivered several loads of backfill material that were placed at the south end of the yard.

CVE fabricators continued forming stem structures.

CVE electricians continued wiring work in the control building.

CVE line crew loaded up structural steel pillars to be transported for re-boring of anchor bolt holes.

Weather was cool, dry, and mostly sunny with highs in the mid 30s. Very slight winds and no precipitation.

PACIFICORP

R & R ENVIRONMENTAL, INC.

3RD WEST SUBSTATION REMEDIATION PROJECT

HEALTH SAFETY MANAGER (HSM)

DAILY CHECKLIST

DATE: 02/24/11

General

NA Work area Health and Safety Inspection

NA Review and if necessary update Activity Hazard Analyses (AHA) based on planned site activities for the day

NA Safety Planning or "Tailgate" mandatory meeting for all employees and contractors prior to commencement of any site work. Instruction, review hazards, health & safety issues and any modifications to the CSHASP

NA Site hazard and safety instruction for all first time employees, contractors or visitors

NA Complete Employee Meeting Record Form B (where applicable)

NA Document required Respirator Training completion with Form H

NA Record times and numbers of dump trucks and trailers as they leave the site with contaminated material.

NA Confirm return of waste material manifest documents for each load with site manager.

NA Complete all CSHASP Forms (for applicable activities planned for that day)

- NA Illness/Injury Report Form A
- NA Site-Specific Training Record Form C
- NA Hot Work Permit Form D
- NA Trench/Evacuation Permit Form E
- NA Combined Space Entry Permit From F
- ☑ Exclusion zone operations are practiced as instructed.
  - ☑ Decontamination unit is working properly.
  - ☑ Workers are using decontamination unit as instructed.
  - ☑ Workers use personal protective equipment properly.

☑ Set air samples at cardinal compass points around exclusion zone. Check throughout the day to ensure proper operation.
Observe control measures for dust and fugitive materials i.e. watering excavation sites and track out prevention.

☑ Review sign-in/sign-out log throughout and at the end of the workday.

☑ Secure the site at the end of the workday

Sampling

NA Soil Confirmation sampling for any newly excavated areas

☑ Stationary Air Monitoring during contaminated soil removal around the perimeter of the exclusion zone

NA Personal Breathing Zone Monitoring on personnel conducting contaminated dust and soil removal

NA Digitally photograph each sample location and at any place field sampling personnel determined necessary

- ☑ Electronically file photo files into the on-site database

- ☑ Complete Field Documentation
  - ☑ Field Sample Data Sheets (FSDS)
  - ☑ Logbook
  - ☑ On-site computer database
- ☑ Label each sample media with a unique number
- ☑ Seal sample(s) in zip lock plastic bags
- ☑ Complete and include Chain of Custody (COC) Form required for shipping of samples to appropriate laboratory
- ☑ Package samples for transport IAW SOP 2-1, Packaging and Shipping of Environmental Samples
- ☑ Review and disseminate sample results as received from the laboratories to Project Manager and other appropriate managers and employees
- ☑ Electronically file sample reports into on-site database

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation Site Project Safety Audit

Project: 3rd West Sub Station **Date:** 02/24/12

Location: 3rd West, 1st South, SLC **Job Number:**

Survey Conducted By: Justin Kargis **Title:**

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.59	Hazard Communication Program, List of Chemicals, Training, MSDSs.			x	
1926.500 (b) & (d) (old standard)	Guardrails on open sided floors, floor holes and runways.			x	
1926.404 (b)	Ground fault circuit interrupters or an assured equipment grounding conductor program in use.	x			
1926.451 (b)	The employer shall instruct each employee in the recognition and avoidance of unsafe conditions.			x	
1926.451 (d)	Tubular welded scaffolds shall be properly braced so that they are plumb, square and rigid; legs on plumb, adjustable, mud sills, etc. to support the maximum load; guardrails and toe boards shall be installed.			x	
1926.100 (a)	Head protection, where there is a possible danger of head injury.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.652 (a) (1)	Excavation protective systems; examination by competent person when less than 5 feet in depth.			x	
1926.20 (b) (2)	Employer responsibility to initiate and maintain safety and health programs.			x	
1926.20 (b) (1)	Employer responsibility to provide for frequent and regular inspections by designated competent persons.			x	
1926.451 (e)	Manually propelled scaffolds shall have tight planking for the full width, platforms secured, ladder or stairway provided, suitable footing, stand plumbs, wheels locked, guardrails and toe boards.			x	
1926.1052 (c) (1)	Stair rail and handrail along each unprotected edge.			x	
1926.25 (a)	Debris, scrap lumber with protruding nails, not cleared for work areas, stairs and around structures.			x	
1926.50	First aid shall be available in the absence of an infirmary, or other that is reasonably accessible; first aid supplies shall be accessible and telephone numbers posted.			x	
1926.451 (a) (13)	Scaffolding safe access not provided by ladder or equivalent.			x	
1926.651 (k) (1)	Excavations, protective systems, inspected daily by a competent person and as needed.			x	
1926.403 (b) (2)	Employer shall ensure electrical equipment is free from recognized hazards, is suitable, used in accordance with the listing, labeling or certification.	x			

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (4)	Scaffolding shall have guardrails and toe boards when more than 10 feet high and when less than 45 inches of work space.			x	
1926.405 (g) (2)	Flexible cords shall be used without splice or tap; strain relief shall be provided.			x	
1926.405 (b)	Electrical boxes, fittings shall have covers, faceplates or canopy and holes shall be smooth where cords pass through; and unused openings in cabinets/boxes shall be closed.	x			
1926.701 (b)	Reinforcing steel onto which employees could fall shall be guarded.			x	
1926.1053 (b) (1)	Portable ladder side rails extend at least 3 feet or be secured at top.			x	
1926.651 (j) (2)	Excavations shall have materials or equipment placed at least 2 feet from the edge.			x	
1926.651 (c) (2)	Excavations shall have a safe means of egress such as ladders, ramps, etc.	x			
1926.150 (c) (1)	Portable fire fighting equipment shall be provided and extinguishers shall be inspected periodically.			x	
1926.102 (a) (1)	Eye and face protection shall be provided.	x			
1926.300 (b) (2)	Guards for power tools shall be used and moving parts of equipment shall be guarded.	x			
1926.350 (a) (9)	Oxygen cylinders in storage shall be separated from fuel gas cylinders by at least 20 feet or a ½ fire resistance barrier.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.405 (a) (2) (ii) (e) & (f)	Temporary lights shall be protected from breakage, not suspended by their cords and extension cord.			X	
1926.405 (a) (2) (ii) (j)	Extension cords used with portable electric tools shall be of three wire type and designed for hard or extra hard usage.	x			
1926.105 (a)	Workplaces more than 25 feet above the ground or water shall have safety nets when ladder, safety line/belts, temporary floors, scaffolds, catch platform are not practical.			x	
1926.1051 (a)	Stairway or ladder shall be provided at all access points where there is a break in elevation of 19 inches or more.	x			
1926.451 (a) (2)	Scaffolding footing or anchorage shall be sound, rigid and capable of carrying the maximum intended load.	x			
1926.500 (c) (1) (old standard)	Wall opening shall be guarded.			x	
1926.404 (f) (7)	Electrical equipment connected by cord and plug shall be grounded except if there is an isolating transformer or the tool is double insulated.	x			
1926.556 (b) (2)	When working from an aerial lift, a full body harness and lanyard attached to the boom or basket.			x	
1926.501 (b) (1) (new standard)	Guardrails, safety nets or personal fall arrest system shall be used at 6 feet or more.			x	

Standard	*Title*	In Compliance ☐	Out of Compliance ☐	N/A ☐	*Corrective Action Taken and Date*
1926.451 (a) (14)	Scaffold planking shall extend over their end support not less than 6 inches and not more than 12 inches.	x			
1926.602 (a) (9)	Bi-directional earth moving equipment shall have audible alarms.	x			
1926.451 (a) (3)	Scaffolding shall be erected, moved, dismantled or altered under the supervision of a competent person.			x	
1926.550 (b) (2)	Cranes, crawler, truck or locomotive, shall meet the design, testing, maintenance, and operation per ANSI B30.5_1968. The most recent certification shall be on file until a new one is prepared.			x	

Comments:

No exclusion zone work done today.

Newman workers did temporarily enter the area with exposed native soil to perform equipment maintenance.

CVE fabricators poured stem structures on spread footings in area south of 2nd transformer.

CVE electricians worked on wiring panels for circuit breakers.



PHOTO 1

PHOTO 2



PHOTO 3



PHOTO 4

R & R Environmental, Inc.
47 West 9000 South, Suite #2, Sandy, Utah 84070
(801) 352-2380 • Fax: (801) 352-2381

PROJECT NO:

DESIGNED BY:	SCALE:	REVIEWED BY: DCR
CREATED BY: JRWC	DATE: 2/20/2012	FILE:

SITE PHOTOGRAPHS

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation
"2011 Upgrade Project"
Salt Lake City, Utah



PHOTO 1



PHOTO 2



PHOTO 3



PHOTO 4

R & R Environmental, Inc.
47 West 9000 South, Suite #2, Sandy, Utah 84070
(801) 352-2380 • Fax: (801) 352-2381

PROJECT NO:

DESIGNED BY:	SCALE:	REVIEWED BY: DCR
DRAWN BY: JMK	DATE 02/21/12	FILE:

SITE PHOTOGRAPHS

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation
"2011 Upgrade Project"
Salt Lake City, Utah



PHOTO 1

PHOTO 2



PHOTO 3

R & R Environmental, Inc.
47 West 9000 South, Suite #2, Sandy, Utah 84070
(801) 352-2380 • Fax: (801) 352-2381

PROJECT NO:

DESIGNED BY:	SCALE:	REVIEWED BY: DCR
DRAWN BY: JMK	DATE 02/22/12	FILE:

SITE PHOTOGRAPHS

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation
"2011 Upgrade Project"
Salt Lake City, Utah



PHOTO 1



PHOTO 2



PHOTO 3



PHOTO 4

R & R Environmental, Inc.
47 West 9000 South, Suite #2, Sandy, Utah 84070
(801) 352-2380 • Fax: (801) 352-2381

PROJECT NO:		
DESIGNED BY:	SCALE:	REVIEWED BY: DCR
DRAWN BY: JMK	DATE 02/23/12	FILE:

SITE PHOTOGRAPHS

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation
"2011 Upgrade Project"
Salt Lake City, Utah

PHOTO 1



PHOTO 2

R & R Environmental, Inc.
47 West 9000 South, Suite #2, Sandy, Utah 84070
(801) 352-2380 • Fax: (801) 352-2381

PROJECT NO:		
DESIGNED BY:	SCALE:	REVIEWED BY: DCR
DRAWN BY: JMK	DATE 02/24/12	FILE:

SITE PHOTOGRAPHS

PACIFICORP
A MIDAMERICAN ENERGY HOLDINGS COMPANY

3rd West Substation
"2011 Upgrade Project"
Salt Lake City, Utah

PACIFICORP OPERATIONS - Field Construction Representative Daily Log

PROJECT NAME:	Third West Sub - Rebuild	**DATE :**	Monday, February 20, 2012
PO & Work Order NO. :	3000078050 / 10035803	**MAIN CONTRACTOR :**	Cache Valley Electric

Crew Start Time:	7:00	**Crew Stop Time:**	17:15	**Tot Hrs mns:**	10:15
FCR Start Time:	6:48	**FCR Stop Time:**	17:30	**Tot Hrs mns:**	10:42

Use military time format *00:00*

WEATHER CONDITIONS: Partly Cloudy, 23 degrees in AM - Cloudy, 40 degrees in PM

DESCRIPTION: (work performed, general comments, instructions to contractor, # of crew members onsite.)

R&R set up four monitors. Newman placed temporary backfill along the west side of the #4 vault, along east and west sides of the west transformer and had a sub come in to core-drill 6" holes in Vaults 4 and 5. CVE Electrical crew wired panels. CVE Line Crew mobilized to the site, received a steel delivery of columns and beams, set grade on levelling nuts. CVE Fab Crew started forming up the eight spread footings and built templates for the anchor bolts. CVE Fab Crew = 6 , CVE Electrical Crew = 3 , CVE Line Crew = 4, Newman = 5, R&R = 1, Wilding = 1.

IF WORKING IN ENERGIZED SUBSTATION:

Dispatcher login, name and time:	Jim Bowman 0648
Dispatcher logout, name and time:	Jim Bowman 1729

DISCREPANCIES:	**IMMEDIATE CORRECTIVE ACTION TAKEN:**
2/20 - Identified possibile issue with bolt projection for "G" and "E" foundations, and base plate hole size issue	Sent e-mail to Mike Shepherd. Discussed with Scott Collard.
11/30 - Identified an additional retaining wall that is below grade and does not show on the Demo Plan.	Will excavate to detennine dimensions.
12/15 - Excavated to locate the 46 kV cables exiting the west side of the yard. Dug 8' and didn't find them. Will try aagin. Actual deoth will be much deeper than design of new bank	Sent e-mail to Roger F.

DELAYS OR LOST TIME ENCOUNTERED:

EQUIPMENT (working, delivered, idle):

CVE fab crew: Portable toilet (2), forklift, 1 dumpster, office trailer, conex , exclusion zone conex, (2), tool trailer, crew truck (2), boom truck. Newman: trachoe (3), loader, bobcat, mini-ex (2), water truck, compactor, backhoe.

OSHA Recordable Safety Incidents:	**Reported by:**	**Time:**

ROCKY MOUNTAIN POWER
A DIVISION OF PACIFICORP

Russ Johnson
Field Construction Representative

PACIFICORP OPERATIONS - Field Construction Representative Daily Log

PROJECT NAME: Third West Sub - Rebuild **DATE :** Tuesday, February 21, 2012

PO & Work Order NO. : 3000078050 / 10035803 **MAIN CONTRACTOR :** Cache Valley Electric

Crew Start Time:	7:00	**Crew Stop Time:**	17:15	**Tot Hrs mns:**	10:15
FCR Start Time:	6:55	**FCR Stop Time:**	17:15	**Tot Hrs mns:**	10:20

Use military time format 00:00

WEATHER CONDITIONS: Cloudy, 34 degrees in AM - Rainy, 40 degrees in PM

DESCRIPTION: (work performed, general comments, instructions to contractor, # of crew members onsite.)

R&R set up four monitors. Newman tied in conduits from the switchgear to Vaults #4 and #5, delivered backfill material into the south excavation area, and excavated the 46 kV duct bank trench from the 46 kV vaults to a point south and east of where it crosses under the 12 kV duct banks. Newman is staging all spoils in the EZ until they are able to demolish the old control building and then remove all of the contaminated materials at once. CVE Line Crew worked on enlarging the holes in the baseplates of the box structure columns, but were not able to set the column. Plan B tbd. CVE Fab Crew completed foming of six of the eight "E" foundations and grouted the form-ty voids in the transfonner pedestal and oil containment walls. They started installation of the grating supports for the oil containment. RMP Comn Tech worked in the new control building. CVE Fab Crew = 6 , CVE Line Crew = 5, Newman = 5, R&R = 1, Wilding = 1.

IF WORKING IN ENERGIZED SUBSTATION:

Dispatcher login, name and time:	Manny LuHaun 0655
Dispatcher logout, name and time:	Ken Barto 1710

DISCREPANCIES:	IMMEDIATE CORRECTIVE ACTION TAKEN:
2/20 - Identified possibile issue with bolt projection for "G" and "E" foundations, and base plate hole size issue	Radha authorized 9" projection for "E" fdns and reaming of holes in baseplates. First attempt at reamino falled to produce results
11/30 - Identified an additional retaining wall that is below grade and does not show on the Demo Plan.	Will excavate to determine dimensions.
12/15 - Excavated to locate the 46 kV cables exiting the west side of the yard. Dug 8' and didn't find them. Will try again. Actual depth will be much deeper than design of new bank	Sent e-mail to Roger F.

DELAYS OR LOST TIME ENCOUNTERED:

Issue with the tolerance of anchor bolt size and holes in the baseplates for the box structure columns. Bolts are 2-1/2" and holes are 2-5/8", which after galvanizing become 2-9/16" holes. CVE attempted to ream the holes with a bore-hone, but after wearing out three sets of stones, they were not successful in removing enough material to be able to set the column.

EQUIPMENT (working, delivered, idle):

CVE fab crew: Portable toilet (2), forklift, 1 dumpster, office trailer, conex , exclusion zone conex, (2), tool trailer, crew truck (2), boom truck. Newman: trachoe (4), loader, bobcat, mini-ex (2), water truck, compactor, backhoe.

OSHA Recordable Safety Incidents:	Reported by:	Time:

ROCKY MOUNTAIN POWER
A DIVISION OF PACIFICORP

Russ Johnson
Field Construction Representative

PACIFICORP OPERATIONS - Field Construction Representative Daily Log

PROJECT NAME: Third West Sub - Rebuild **DATE :** Wednesday, February 22, 2012

PO & Work Order NO. : 3000078050 / 10035803 **MAIN CONTRACTOR :** Cache Valley Electric

Crew Start Time:	7:00	**Crew Stop Time:**	17:25	**Tot Hrs mns:**	10:25
FCR Start Time:	6:45	**FCR Stop Time:**	17:25	**Tot Hrs mns:**	10:40

Use military time format 00:00

WEATHER CONDITIONS: Cloudy, 35 degrees in AM - Cloudy, 45 degrees in PM

DESCRIPTION: (work performed, general comments, instructions to contractor, # of crew members onsite.)

R&R set up four monitors. Newman completed the section of 46 kV trench just south of the 46 kV vaults and installed four 6" conduits. Newman delivered backfill material into the south excavation area. Newman is staging all spoils in the EZ until they are able to demolish the old control building and then remove all of the contaminated materials at once. CVE Line Crew showed up this morning but went home until a resolution is determined for the baseplate issue. CVE thinks they have a reamer solution for the baseplates. CVE Fab Crew completed forming the last two of the eight "E" foundations and started squaring up the forms in preparation for setting the anchor bolts and pouring the stems on Thursday. They completed the installation of the grating supports for the oil containment and placed the grating. RMP Comm Techs worked in the new control building. CVE Electrical Crew wired panels in the new control building CVE Fab Crew = 6 , Newman = 5, R&R = 1, Wilding = 1.

IF WORKING IN ENERGIZED SUBSTATION:

Dispatcher login, name and time:	Manny LuHaun 0645
Dispatcher logout, name and time:	??????? 1725

DISCREPANCIES:	IMMEDIATE CORRECTIVE ACTION TAKEN:
2/20 - Identified possibile issue with bolt projection for "G" and "E" foundations, and base plate hole size issue	CVE thinks they have a reamer solution for the anchor bolt/baseplate issue
11/30 - Identified an additional retaining wall that is below grade and does not show on the Demo Plan.	Will excavate to determine dimensions.
12/15 - Excavated to locate the 46 kV cables exiting the west side of the yard. Dug 8' and didn't find them. Will try again. Actual depth will be much deeper than design of new bank	Sent e-mail to Roger F.

DELAYS OR LOST TIME ENCOUNTERED:

CVE Line Crew has pulled off the site until the anchor bolt/baseplate issue is resolved.

EQUIPMENT (working, delivered, idle):

CVE fab crew: Portable toilet (2), fbrklift, 1 dumpster, office trailer, conex , exclusion zone conex, (2), tool trailer, crew truck (2), boom truck. Newman: trachoe (4), loader, bobcat, mini-ex (2), water truck, compactor, backhoe.

OSHA Recordable Safety Incidents:	Reported by:	Time:

ROCKY MOUNTAIN POWER
A DIVISION OF PACIFICORP

Russ Johnson
Field Construction Representative

PACIFICORP OPERATIONS - Field Construction Representative Daily Log

PROJECT NAME: Third West Sub - Rebuild **DATE :** Thursday, February 23, 2012

PO & Work Order NO. : 3000078050 / 10035803 **MAIN CONTRACTOR :** Cache Valley Electric

Crew Start Time:	7:00	**Crew Stop Time:**	5:25	**Tot Hrs mns:**	22:25
FCR Start Time:	6:45	**FCR Stop Time:**	5:30	**Tot Hrs mns:**	22:45

Use *mili*tary *time* format ***00:00***

WEATHER CONDITIONS: Partly Cloudy, Breezy - 28 degrees in AM; 40 degrees in PM

DESCRIPTION: (work performed, general comments, instructions to contractor, # of crew members onsite.)

R&R set up four monitors. Newman extended the 46 kV duct bank trench to a point south of the switchgear foundation so their trench excavation will not interfere with the switchgear building when it is set on Monday. They wrecked out concrete and spoils in the old 46y kV yard and hauled in ABC for backfilling of the spread footing area. CVE Line Crew (two people) showed up this morning long enough to load out the box structure columns for shipping to a fab shop that will ream out the base plate holes. CVE Fab Crew set anchor bolts and squared up foundations for an 11:00 AM pour on Friday. CVE Electrical Crew completed wiring of the panels in the new control building and cleaned up the building. CVE Fab Crew = 6 , CVE Line Crew = 2, CVE Electrical Crew = 3, Newman = 4, R&R = 1, Welding = 1.

IF WORKING IN ENERGIZED SUBSTATION:

Dispatcher login, name and time:	Blake Spence 0647
Dispatcher logout, name and time:	?????????????1730

DISCREPANCIES:	**IMMEDIATE CORRECTIVE ACTION TAKEN:**
2/20 - Identified possibile issue with bolt projection for "G" and "E" foundations, and base plate hole size issue	Columns on site were hauled to shop to have base plate holes reamed out.
11/30 - Identified an additional retaining wall that is below grade and does not show on the Demo Plan.	Will excavate to determine dimensions.
12/15 - Excavated to locate the 46 kV cables exiting the west side of the yard. Dug 8' and didn't find them. Will try again. Actual depth will be much deeper than design of new bank	Sent e-mail to Roger F.

DELAYS OR LOST TIME ENCOUNTERED:

CVE Line Crew has pulled off the site until the anchor bolt/baseplate issue is resolved.

EQUIPMENT (working, delivered, idle):

CVE fab crew: Portable toilet (2), forklift, 1 dumpster, office trailer, conex , exclusion zone conex, (2), tool trailer, crew truck (2), boom truck. Newman: trachoe (4), loader, bobcat, mini-ex (2), water truck, compactor, backhoe.

OSHA Recordable Safety Incidents:	**Reported by:**	**Time:**

ROCKY MOUNTAIN POWER
A DIVISION OF PACIFICORP

Russ Johnson
Field Construction Representative

PACIFICORP OPERATIONS - Field Construction Representative Daily Log

PROJECT NAME:	Third West Sub - Rebuild	**DATE :**	Friday, February 24, 2012
PO & Work Order NO. :	3000078050 / 10035803	**MAIN CONTRACTOR :**	Cache Valley Electric

Crew Start Time:	7:00	**Crew Stop Time:**	16:10	**Tot Hrs mns:**	9:10
FCR Start Time:	6:45	**FCR Stop Time:**	16:15	**Tot Hrs mns:**	9:30

Use military time format 00:00

WEATHER CONDITIONS: Sunny- 25 degrees in AM, Sunny 45 degrees in PM

DESCRIPTION: (work performed, general comments, instructions to contractor, # of crew members onsite.)

R&R set up four monitors. Newman performed some maintenance on their equipment as they are held up until CVE gets the spread footings stripped, allowing Nevrman to backfill the south excavation area. CVE Fab Crew finalized anchor bolt placement and poured 24 cyds of concrete in the spread footer stems ("E" fdns). The first truck falled the air test. Second truck passed both air and slump. CVE Electrical Crew installed boxes and gutters in the eastd 138 kV yard CVE Fab Crew = 6 , CVE Electrical Crew = 3, Newman = 4, R&R = 1, Wilding = 1.

IF WORKING IN ENERGIZED SUBSTATION:

Dispatcher login, name and time:	Bany Nielson 0645
Dispatcher logout, name and time:	Ken Barto 1615

DISCREPANCIES:	**IMMEDIATE CORRECTIVE ACTION TAKEN:**
2/20 - Identified possibile issue with bolt projection for "G" and "E" foundations, and base plate hole size issue	Columns have been moved to fab shop for reaming of base plat holes.
11/30 - Identified an additional retaining wall that is below grade and does not show on the Demo Plan.	Will excavate to determine dimensions.
12/15 - Excavated to locate the 46 kV cables exiting the west side of the yard. Dug 8' and didn't find them. Will try again. Actual deoth will be much deeper than design of new bank	Sent e-mail to Roger F.

DELAYS OR LOST TIME ENCOUNTERED:

CVE Line Crew has pulled off the site until the anchor bolt/baseplate issue is resolved.

EQUIPMENT (working, delivered, idle):

CVE fab crew: Portable toilet (2), forklift, 1 dumpster, office trailer, conex , exclusion zone conex, (2), tool trailer, crew truck (2), boom truck. Newman: trachoe (4), loader, bobcat, mini-ex (2), water truck, compactor, backhoe.

OSHA Recordable Safety Incidents:	**Reported by:**	**Time:**

ROCKY MOUNTAIN POWER
A DIVISION OF PACIFICORP

Russ Johnson
Field Construction Representative

REI LAB Reservoirs Environmentoi, Inc.

February 22, 2012

Laboratory Code:	RES
Subcontract Number:	NA
Laboratory Report:	RES 230171-1
Project # / P.O. #	None Given
Project Description:	RMP - 3rd W. Sub

Eldon Romney
R & R Environmental
47 West 9000 South #2
Sandy UT 84070

Dear Customer,

Reservoirs Environmental, Inc. is an analytical laboratory accredited for the analysis of Industrial Hygiene and Environmental matrices by the National Voluntary Laboratory Accreditation Program (NVLAP), Lab Code 101896-0 for Transmission Electron Microscopy (TEM) and Polarized Light Microscopy (PLM) analysis and the American Industrial Hygiene Association (AIHA), Lab ID 101533 - Accreditation Certificate #480 for Phase Contrast Microscopy (PCM) analysis. This laboratory is currently proficient in both Proficiency Testing and PAT programs respectively.

Reservoirs Environmental, Inc. has analyzed the following samples for asbestos content as per your request. The analysis has been completed in general accordance with the appropriate methodology as stated in the attached analysis table. The results have been submitted to your office.

RES 230171-1 is the job number assigned to this study. This report is considered highly confidential and the sole property of the customer. Reservoirs Environmental, Inc. will not discuss any part of this study with personnel other than those of the client. The results described in this report only apply to the samples analyzed. This report must not be used to claim endorsement of products or analytical results by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except In full, without written approval from Reservoirs Environmental, Inc. Samples will be disposed of after sixty days unless longer storage is requested. If you have any questions about this report, please feel free to call 303-964-1986.

Sincerely,

Jeanne Spencer Orr
President

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE I. TEM AIR FILTER SAMPLE DATA AND ANALYTICAL RESULTS

RES Job Number:	RES 230171-1
Client:	R & R Environmental
Client Project Number / P.O.:	None Given
Client Project Description:	RMP - 3rd W. Sub
Date Samples Received:	February 21, 2012
Analysis Type:	TEM, AHERA
Turnaround:	24 Hour
Date Samples Analyzed:	February 22, 2012

Client ID Number	Lab ID Number	Area Analyzed	Air Volume Sampled	Number of Asbestos Structures Detected	Analytical Sensitivity	Asbestos Concentration	Filter Loading
		(mm^2)	(L)		(s/cc)	(s/cc)	(s/mm^2)
3W0220-N	EM 867009	0.0700	1152	ND	0.0048	BAS	BAS
3W0220-S	EM 867010	0.0700	1152	ND	0.0048	BAS	BAS
3W0220-E	EM 867011	0.0700	1150	ND	0.0048	BAS	BAS
3W0220-W	EM 867012	0.0700	1150	ND	0.0048	BAS	BAS
Blank (Sample Not Labeled)	EM 867013	NA	0	NA	—	—	—
Blank (Sample Not Labeled)	EM 867014	NA	0	NA	—	—	—

NA = Not Analyzed
ND = None Detected
BAS = Below Analytical Sensitivity
Average Grid Opening in mm^2 = 0.010

Filter Material = Mixed Cellulose Ester
Filter Diameter = 25 mm
Effective Filter Area = 385 sq mm

DATA QA

RES 230171

Due Date: 2-22-12
Due Time: 5pm

Reservoirs Environmental, Inc.

5801 Logan St. Denver, CO 80216 • Ph: 303 964-1986 • Fax 303-477-4278 • Toll Free :866 RESI-ENV
Pager : 303-509-2096

Page 1 of 1

INVOICE TO: (IF DIFFERENT)

Company: R+R Environmental, Inc	Company:
Address: 471 W, 9000 S., #2 Sandy, UT 84070	Address:
Project Number and/or P.O. #:	
Project Description/Location: RAP - 8375 S. 378 W. Smb.	

CONTACT INFORMATION:

Contact: Dave Rosebery	Contact:
Phone: 801.541.1035	Phone:
Fax:	Fax:
Cell/pager:	Cell/pager:
Final Data Deliverable Email Address: DAVE@RRENVIRO.COM	

ASBESTOS LABORATORY HOURS: Weekdays: 7am - 7pm

PLM / PCM / (TEM) ___ RUSH (Same Day) X PRIORITY (Next Day) ___ STANDARD
(Rush PCM = 2hr, TEM = 6hr.)

CHEMISTRY LABORATORY HOURS: Weekdays: 8am - 5pm

Metal(s) / Dust ___ RUSH ___ 24 hr. ___ 3-5 Day
RCRA S / Metals & Welding Fume Scan / TCLP ___ RUSH ___ 5 day ___ 10 day
Organics ___ 24 hr. ___ 3 day ___ 5 Day

Prior notification is required for RUSH turnarounds.

MICROBIOLOGY LABORATORY HOURS: Weekdays: 9am - 6pm

E.coli O157:H7, Coliforms, S.aureus ___ 24 hr. ___ 2 Day ___ 3-5 Day
Salmonella, Listeria, E.coli, APC, Y & M ___ 48 Hr. ___ 3-5 Day
Mold ___ RUSH ___ 24 Hr ___ 48 Hr ___ 3 Day ___ 5 Day

Turnaround times establish a laboratory priority, subject to laboratory volume and are not guaranteed. Additional fees apply for after hours, weekends and holidays.

Special Instructions:

REQUESTED ANALYSIS

Client sample ID number (Sample ID's must be unique)	PLM - Short report, Long report, Point Count	TEM - AHERA, Level II, 7402, ISO, +/-, Quant. Semi-quant, Micro-vac, ISO-Indirect Preps	PCM - 7400A, 7400B, OSHA	DUST - Total, Respirable	METALS - Analyte(s) RCRA 8, TCLP, Welding Fume, Metals Scan	ORGANICS - METH	MICROBIOLOGY: Salmonella: +/-	E.coli O157:H7: +/-	Listeria: +/-	Aerobic Plate Count: +/- or Quantification	E.coli: +/- or Quantification	Coliforms: +/- or Quantification	S.aureus: +/- or Quantification	Y & M: +/- or Quantification	Mold: +/-, Identification, Quantification	SAMPLER'S INITIALS OR OTHER NOTES	Sample Volume (L) / Area	Matrix Code	# Containers	Date Collected mm/dd/yy	Time Collected hh/mm a/p	EM Number (Laboratory Use Only)
1 3W0220-M	X	AHERA															1,152	B		2/20/12		867500
2 -S																	1,152					10
3 -E																	1,150					11
4 -W																	1,150					12
5 Blank (Sample not labeled)																						13
6 Blank (Sample not labeled)																						14
7																						
8																						
9																						
10																						

VALID MATRIX CODES

Air = A	Bulk = B
Dust = D	Paint = P
Soil = S	Wipe = W
Swab = SW	F = Food
Drinking Water = DW	Waste Water = WW
O = Other	

ASTM E1792 approved wipe media only

LAB NOTES:

Number of samples received: 6 (Additional samples shall be listed on attached long form.)

NOTE: REI will analyze incoming samples based upon information received and will not be responsible for errors or omissions in calculations resulting from the inaccuracy of original data. By signing client/company representative agrees that submission of the following samples for requested analysis as indicated on this Chain of Custody shall constitute an analytical services agreement with payment terms of NET 30 days, failure to comply with payment terms may result in a 1.5% monthly interest surcharge.

Relinquished By: [signature] 2/20/12 Date/Time: 1800

Laboratory Use Only
Received By: Date/Time: 2/21/12 8:30 am Carrier: Fedex

Sample Condition: On Ice Yes / No; Sealed Yes / No; Intact (Yes) / No
Temp. (F°) ____

Results:	Contact	Phone	Email	Fax	Date	Time	Initials	Contact	Phone	Email	Fax	Date	Time	Initials
	Contact	Phone	Email	Fax	Date	Time	Initials	Contact	Phone	Email	Fax	Data	Time	Initials

Heating #: 8675 3828 4026

Attachment I

Key to Count Sheets
Count Sheets
Analytical Procedures

Structures identifications consist of an Asbestos Type followed by a Structure Type

Asbestos Type	Structure Types
A = Amosite	F = Fiber
An = Anthophyllite	B = Bundle
C = Chrysotile	C = Cluster
Cr = Crocidolite	M = Matrix
T = Tremolite	

ND = no structures detected
M = other structure associated with a matrix
NAM = Non Asbestos Mineral
XGB = partly obscured by a grid bar

Sizing Conversion
1 length unit = 5 mm on screen = 0.278 micron
1.80 length units = 0.5 micron
18.0 length units = 5 microns

1 width unit = 1 mm on screen = 0.0556 micron

TEM Analysts

Jeanne S. Orr
Nathan DelHierro
Angela Heitger
Jonathan Bernard
Paul D. LoScalzo
Mark Steiner
Norberto Zimbleman
Robert Workman



Upper and lower 95% confidence bounds for the number of structures counted assuming a Poisson distribution.

Reservoirs Environmental, Inc.
***TEM* Asbestos Structure Count**

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	RVR
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	1152
Date received by lab	2/21/12
Lab Job Number	230171
Lab Sample Number	867009

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	F3-1	ND												
	E3-1	ND			Pmp		A	80% in Sect		5-10% debris				
	C3-6	ND			Pmp		B	60% in Sect		5-10% debris				
	B3-6	ND												
B	H5-3	ND												
	G5-3	ND												
	F5-3	ND												

JB 2/22/12

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (II) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Sampla Tyoe (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	1152
Data received by lab	2/21/12
Lab Job Number:	230171
Lab Sampla Number:	807010

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	DB
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirecl, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Stmcture Type	No. of Structures		Ditnensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	L5-4	ND												
	K5-4	ND												
	H5-4	ND			Pmps		AmB	~60% cmfmf			5% debris			
	G5-4	ND												
B	K4-6	ND									2/22/12			
	H4-6	ND												
	G4-6	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	1150
Date recaivad by lab	2/21/12
Lab Job Number:	23017.1
Lab Sample Number:	34011

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Voluma (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	ATH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	F4-3	ND												
	E4-3	ND				Prep	A	60% in front			3-5% debris			
	B4-6	ND				Prep	B	50% in front			3-5% debris			
	A4-6	ND												
B	F4-6	ND								B	2/22/12			
	E4-6	ND												
	C4-6	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysolile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Samole Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	150
Date received by lab	2/21/12
Lab Job Number:	230172
Lab Sample Numben	40702

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filtar used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/24/12
Method (O=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	F3-6	ND												
	E3-6	ND					Pop A	70% cement		5-7% debris				
	C3-6	ND					Pop B	80% cement		5-7% debris				
	B3-6	ND												
B	H4-4	ND						JB 2/22/12						
	G4-4	ND												
	F4-4	ND												

I.A = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Analytical Procedures – AHERA

Transmission electron microscopy/energy dispersive X-ray spectrometry/selected area electron diffraction (TEM/EDX/SAED) was erhployed in the analysis of the samples, which were collected on 25 mm mixed cellulose ester air filters. A portion of each filter was collapsed with acetone and etched in a plasma asher. The etched filter was then coated with a thin layer of carbon in a carbon side down. The sample was then placed inside a condensation washer and treated with acetone to remove the filter matrix and expose any inert material.

For each sample, enough grid openings on a 200 mesh TEM grid are analyzed to ensure an analytical sensitivity of at least 0.005 structures/cc. A minimum of four grid openings from two preparations are analyzed for each sample. The grid openings are searched for fibrous structures which, if present are analyzed by SAED and/or EDX (elemental analysis). The AHERA protocol requires SAED confirmation of enough chrysotile asbestos structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures). Both SAED and EDX confirmation are required of enough amphibole structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures) per sample. Either SAED or EDX is required for the remaining asbestos structures of either type. The morphology of each structure is determined and the length and the diameter of any asbestos structures are recorded. Asbestos fibers, bundles, cluster and matrices were identified and recorded. The asbestos structures have been defined in AHERA as follows:

Fiber:	is a structure having a minimum length greater than or equal to 0.5 micron with an aspect ratio of 5:1 or greater with substantially parallel sides.
Bundle:	is a structure composed of three or more fibers in parallel arrangement, with each fiber closer than the diameter of one fiber.
Cluster:	is a structure with fibers in random arrangements such that all fibers are intermixed and no single fiber is isolated from the group.
Matrix:	is a fiber or fibers with one end free and the other end embedded or hidden by a particulate. The exposed fiber end must meet the fiber definition given above.

If more than 50 asbestos structures are identified and confirmed on a sample, AHERA analysis may be terminated after completion of the grid opening, which contains the 50^{th} structure. AHERA protocol requires the laboratory to reject any clearance sample which contains in excess of 25% total particulate loading or which appears to be unevenly loaded.

The AHERA protocol includes specific sampling requirements, including minimum numbers of samples and minimum air volumes. Specifically, the 70 structures/mm^2 clearance criteria is only allowed for sets five inside samples (collected in a group of 13 samples including: five outsides and three blanks) with volumes greater than 1200 liters (40 CFR Part 763, page 41894). Deviation from the AHERA sampling protocol may affect the validity of the analytical results. Analysis of samples collected by non-protocol methods are not accredited by NVLAP

Equations Used for Calculations

$$\text{Area Analyzed, } mm^2 = \#\text{ GO counted} \times \text{Average GO Area (mm)}$$

$$\text{Concentration, s/cc} = \frac{\#\text{ Asbestos Structures}}{\#\text{ GO Counted}} \times \frac{1}{\text{Volume (L)}} \times \frac{\text{Eff. Filter Area } (mm^2)}{\text{Average GO area } (mm^2)} \times \frac{1L}{1000cc}$$

$$\text{Filter loading, s/mm2} = \frac{\#\text{ Asbestos structures}}{\text{Area Analyzed } (mm^2)}$$

GO = TEM grid opening

File: Shared on server T/Offforms.sg/AHERA Procedures
Revised: 02/27/02

REI LAB Reservoirs Environmentol, Inc.

February 23, 2012

Laboratory Code:	RES
Subcontract Number:	NA
Laboratory Report:	RES 230254-1
Project # / P.O. #	None Given
Project Description:	3rd West Sub - RMP

Eldon Romney
R & R Environmental
47 West 9000 South #2
Sandy UT 84070

Dear Customer,

Reservoirs Environmental, Inc. is an analytical laboratory accredited for the analysis of Industrial Hygiene and Environmental matrices by the National Voluntary Laboratory Accreditation Program (NVLAP), Lab Code 101896-0 for Transmission Electron Microscopy (TEM) and Polarized Light Microscopy (PLM) analysis and the American Industrial Hygiene Association (AIHA), Lab ID 101533 - Accreditation Certificate #480 for Phase Contrast Microscopy (PCM) analysis. This laboratory is currently proficient in both Proficiency Testing and PAT programs respectively.

Reservoirs Environmental, Inc. has analyzed the following samples for asbestos content as per your request. The analysis has been completed in general accordance with the appropriate methodology as stated in the attached analysis table. The results have been submitted to your office.

RES 230254-1 is the job number assigned to this study. This report is considered highly confidential and the sole property of the customer. Reservoirs Environmental, Inc. will not discuss any part of this study with personnel other than those of the client. The results described in this report only apply to the samples analyzed. This report must not be used to claim endorsement of products or analytical results by NVLAP or any agency of the U.S. Govemment. This report shall not be reproduced except in full, without written approval from Reservoirs Environmental, Inc. Samples will be disposed of after sixty days unless longer storage is requested. If you have any questions about this report, please feel free to call 303-964-1986.

Sincerely,

Jeanne Spencer Orr
President

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE I. TEM AIR FILTER SAMPLE DATA AND ANALYTICAL RESULTS

RES Job Number:	RES 230254-1
Client:	R & R Environmental
Client Project Number / P.O.:	None Given
Client Project Description:	3rd West Sub - RMP
Date Samples Received:	February 22, 2012
Analysis Type:	TEM, AHERA
Turnaround:	24 Hour
Date Samples Analyzed:	February 23, 2012

Client ID Number	Lab ID Number	Area Analyzed	Air Volume Sampled	Number of Asbestos Structures Detected	Analytical Sensitivity	Asbestos Concentration	Filter Loading
		(mm^2)	(L)		(s/cc)	(s/cc)	(s/mm^2)
3W-022112 S	EM 867453	0.0900	961	ND	0.0045	BAS	BAS
3W-022112 W	EM 867454	0.0900	947	1	0.0045	0.0045	11.1
3W-022112 N	EM 867455	0.1000	210	ND	0.0183	BAS	BAS
3W-022112 E	EM 867456	0.0900	952	ND	0.0045	BAS	BAS

NA = Not Analyzed
ND = None Detected
BAS = Below Analytical Sensitivity
Average Grid Opening in mm^2 = 0.010

Filter Material = Mixed Cellulose Ester
Filter Diameter = 25 mm
Effective Filter Area = 385 sq mm

DATA QA

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101890-0; TDH: #30-0015

TABLE II. SUMMARY OF ANALYTICAL DATA

RES Job Number: RES 230254-1
Client: R & R Environmental
Client Project Number / P.O.: None Given
Client Project Description: 3rd West Sub - RMP
Date Samples Received: February 22, 2012
Analysis Type: TEM, AHERA
Turnaround: 24 Hour
Date Samples Analyzed: February 23, 2012

Client ID Number	Lab ID Number		Asbestos Mineral	Asbestos Structure Types*				Structures >5 Microns in Length	**Excluded Structures	Asbestos Structures for Concentration
				Fibers	Bundles	Clusters	Matrices			
3W-022112 S	EM	867453	ND	0	0	0	0	0	0	0
3W-022112 W	EM	867454	Chrysotile	0	0	1	0	0	0	1
3W-022112 N	EM	867455	ND	0	0	0	0	0	0	0
3W-022112 E	EM	867456	ND	0	0	0	0	0	0	0

*See Analytical Procedure for definitions
**C = Excluded from total due to lack of confirmation
**L = Excluded from total for length less than 0.5 micron (AHERA only)
**A = Excluded from total due to incorrect aspect ratio
ND = None Detected

RES 230254

Due Date: 2-23-12
Due Time: 855a

REI LAB **Reservoirs Environmental, Inc.**

8601 Logan St. Denver, CO 80216 • Ph: 303 964-1986 • Fax 303-477-4275 • Toll Free :866 RESI-ENV
Pager : 303-509-2096

JOB #: ______
Page 1 of 1

Company: R&R Environmental	INVOICE TO: (IF DIFFERENT) Company:	CONTACT INFORMATION: Contact: Dave Roskelley	Contact:
Address: 47 W 9000 S. #2	Address:	Phone:	Phone:
Sandy Ut - 84070		Fax:	Fax:
		Cell/pager: 801 541-1035	Cell/pager:
Project Number and/or P.O. #:		Final Data Deliverable Email Address: dave@rrenviro.com	
Project Description/Location: 30 West Sub-RMP			

ASBESTOS LABORATORY HOURS: Weekdays: 7am - 7pm
PLM / PCM / (TEM) ___ RUSH (Same Day) X PRIORITY (Next Day) ___ STANDARD
(Rush PCM = 2hr, TEM = 6hr.)

CHEMISTRY LABORATORY HOURS: Weekdays: 8am - 5pm
Metal(s) / Dust ___ RUSH ___ 24 hr. ___ 3-5 Day
RCRA 8 / Metals & Welding Fume Scan / TCLP ___ RUSH ___ 5 day ___ 10 day
Organics ___ 24 hr. ___ 3 day ___ 5 Day
Prior notification is required for RUSH turnarounds.

MICROBIOLOGY LABORATORY HOURS: Weekdays: 9am - 6pm
E.coli O157:H7, Coliforms, S.aureus ___ 24 hr. ___ 2 Day ___ 3-5 Day
Salmonella, Listeria, E.coli, APC, Y & M ___ 48 Hr. ___ 3-5 Day
Mold ___ RUSH ___ 24 Hr ___ 48 Hr ___ 3 Day ___ 5 Day

Turnaround times establish a laboratory priority, subject to laboratory volume and are not guaranteed. Additional fees apply for afterhours, weekends and holidays.

Special Instructions:

VALID MATRIX CODES
Air = A; Bulk = B; Dust = D; Paint = P; Soil = S; Wipe = W; Swab = SW; F = Food; Drinking Water = DW; Waste Water = WW; O = Other
ASTM E1792 approved wipe media only

LAB NOTES:

REQUESTED ANALYSIS

#	Client sample ID number (Sample ID's must be unique)	PLM - Short report, Long report, Point Count	TEM - AHERA, Level II, 7402, ISO, +/-, Quant, Semi-quant, Micro-vac, ISO-Indirect Preps	PCM - 7400A, 7400B, OSHA	DUST - Total, Respirable	METALS - Analyte(s) RCRA 8, TCLP, Welding Fume, Metals Scan	ORGANICS - METH	Salmonella: +/-	E.coli O157:H7: +/-	Listeria: +/-	Aerobic Plate Count: +/- or Quantification	E.coli: +/- or Quantification	Coliforms: +/- or Quantification	S.aureus: +/- or Quantification	Y & M: +/- or Quantification	Mold: +/-, Identification, Quantification	SAMPLER'S INITIALS OR OTHER NOTES	Sample Volume (L) / Area	Matrix Code	# Containers	Date Collected mm/dd/yy	Time Collected hh/mm a/p	EM Number (Laboratory Use Only)
1	3W-022112S		X															961	A		2/21/12		867453
2	3W-022112W		↓															947	↓		↓		54
3	3W-022112N		↓															210	↓		↓		55
4	3W-022112E		↓															952	↓		↓		56
5																							
6																							
7																							
8																							
9																							
10																							

MICROBIOLOGY

Number of samples received: (4) (Additional samples shall be listed on attached long form.)

NOTE: REI will analyze incoming samples based upon information received and will not be responsible for errors or omissions in calculations resulting from the inaccuracy of original data. By signing client/company representative agrees that submission of the following samples for requested analysis as indicated on this Chain of Custody shall constitute an analytical services agreement with payment terms of NET 30 days, failure to comply with payment terms may result in a 1.5% monthly interest surcharge.

Relinquished By: [signature] FedEx Date/Time: 2/21/12

Laboratory Use Only
Received By: [signature] Date/Time: 2-22-12 @ 855a Carrier: FedEx

Sample Condition: On Ice Yes / No; Sealed Yes / No; Intact (Yes) / No
Temp. (F°) ______

Results:	Contact	Phone Email Fax	Date	Time	Initials	Contact	Phone (Email) Fax	Date	Time	Initials
	Contact	Phone Email Fax	Date	Time	Initials	Contact	Phone Email Fax	Date	Time	Initials

Tracking #: 7988 0513 8563

7-2011_version 1

Attachment I

Key to Count Sheets
Count Sheets
Analytical Procedures

Structures identifications consist of an Asbestos Type followed by a Structure Type

Asbestos Type	Structure Types
A = Amosite	F = Fiber
An = Anthophyllite	B = Bundle
C = Chrysotile	C = Cluster
Cr = Crocidolite	M = Matrix
T = Tremolite	

ND = no structures detected
M = other structure associated with a matrix
NAM = Non Asbestos Mineral
XGB = partly obscured by a grid bar

Sizing Conversion
1 length unit = 5 mm on screen = 0.278 micron
1.80 length units = 0.5 micron
18.0 length units = 5 microns

1 width unit = 1 mm on screen = 0.0556 micron

TEM Analysts

Jeanne S. Orr
Nathan DelHierro
Angela Heitger
Jonathan Bernard
Paul D. LoScalzo
Mark Steiner
Norberto Zimbleman
Robert Workman



Upper and lower 95% confidence bounds for the number of structures counted assuming a Poisson distribution.

Reservoirs Environmental, Inc.
TEM Asbestos *Structure Count*

Laboratory name:	REI
Instrument	JEOL 100 CX N (S)
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	P+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	361
Date received by lab	2/22/12
Lab Job Number:	230254
Lab Sample Number:	867453

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	MK
Analysis date	2/22/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amohibole	C	NAM		Sketch	Photo	EDS
A	G5-3	ND												
	F5-3	ND			Prep A		70% intact ~5% debris							
	E5-3	ND			Prep B		80% intact ~5% debris				Jan/JC 2/22/12			
	C5-3	ND												
	B5-3	ND												
B	H5-3	ND												
	G5-3	ND												
	F5-3	ND												
	E5-3	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	947
Date received by lab	2/22/12
Lab Job Number:	230254
Lab Sample Number:	867454

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/23/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Glass			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	H5-3	ND												
	G5-3	ND				Prep A		80% cmf		3-5%	debris			
	F5-3	ND				Prep B		80% cmf		3-5%	debris			
	E5-3	ND												
	C5-3	ND												
B	G2-3	C		1	12	12	CD		✓		~~Str~~			
	F2-3	ND												
	E2-3	ND						JB 2/23/12						
	C2-3	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Samole Type (A=Air, D=Dust):	A
Airvolume (L) or dust area (cm2)	210
Date received by lab	2/22/12
Lab Job Number:	23025H
Lab Sample Number:	86455

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volums Applied to secondary filter (ml)	

Analyzed by	DS
Analysis date	2/23/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amohlbole	C	NAM		Sketch	Photo	EDS
A	L3-3	ND												
	H3-3	ND					Prep A	80% int		3-5% debris				
	H3-3	ND					Prep B	80% int		3-5% debris				
	F3-3	ND												
	E3-3	ND												
B	L4-6	ND						LB	2/23/12					
	K4-6	ND												
	H4-6	ND												
	G4-6	ND												
	F4-6	ND												

LA = Libby-type amphlbole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (b) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Sample Tvoe (A=Air, D=Dust):	A
Air vdlume (L) or dust area (cm2)	952
Date received by lab	2/22/12
Lab Job Number:	423454
Lab Sample Number:	86460

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volums Applied to secondary filter (ml)	

Analyzed by	SAB
Analysis date	2/23/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	I
Counting rules (ISO, AHERA, ASTM)	AHERA
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	G4-4	ND												
	F4-4	ND					Prep A	80% content			5-10% debris			
	E4-4	ND					Prep B	60% content			5-10% debris			
	K3-1	ND												
	H3-1	ND							AB	2/23/12				
B	K3-6	ND												
	H3-6	ND												
	G3-6	ND												
	F3-6	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Analytical Procedures – AHERA

Transmission electron microscopy/energy dispersive X-ray spectrometry/selected area electron diffraction (TEM/EDX/SAED) was employed in the analysis of the samples, which were collected on 25 mm mixed cellulose ester air filters. A portion of each filter was collapsed with acetone and etched in a plasma asher. The etched filter was then coated with a thin layer of carbon in a carbon side down. The sample was then placed inside a condensation washer and treated with acetone to remove the filter matrix and expose any inert material.

For each sample, enough grid openings on a 200 mesh TEM grid are analyzed to ensure an analytical sensitivity of at least 0.005 structures/cc. A minimum of four grid openings from two preparations are analyzed for each sample. The grid openings are searched for fibrous structures which, if present are analyzed by SAED and/or EDX (elemental analysis). The AHERA protocol requires SAED confirmation of enough chrysotile asbestos structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures). Both SAED and EDX confirmation are required of enough amphibole structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures) per sample. Either SAED or EDX is required for the remaining asbestos structures of either type. The morphology of each structure is determined and the length and the diameter of any asbestos structures are recorded. Asbestos fibers, bundles, cluster and matrices were identified and recorded. The asbestos structures have been defined in AHERA as follows:

Fiber:	is a structure having a minimum length greater than or equal to 0.5 micron with an aspect ratio of 5:1 or greater with substantially parallel sides.
Bundle:	is a structure composed of three or more fibers in parallel arrangement, with each fiber closer than the diameter of one fiber.
Cluster:	is a structure with fibers in random arrangements such that all fibers are intermixed and no single fiber is isolated from the group.
Matrix:	is a fiber or fibers with one end free and the other end embedded or hidden by a particulate. The exposed fiber end must meet the fiber definition given above.

If more than 50 asbestos structures are identified and confirmed on a sample, AHERA analysis may be terminated after completion of the grid opening, which contains the 50^{th} structure. AHERA protocol requires the laboratory to reject any clearance sample which contains in excess of 25% total particulate loading or which appears to be unevenly loaded.

The AHERA protocol includes specific sampling requirements, including minimum numbers of samples and minimum air volumes. Specifically, the 70 structures/mm^2 clearance criteria is only allowed for sets five inside samples (collected in a group of 13 samples including: five outsides and three blanks) with volumes greater than 1200 liters (40 CFR Part 763, page 41894). Deviation from the AHERA sampling protocol may affect the validity of the analytical results. Analysis of samples collected by non-protocol methods are not accredited by NVLAP

Equations Used for Calculations

$$\text{Area Analyzed, } mm^2 = \#\text{ GO counted} \times \text{Average GO Area (mm)}$$

$$\text{Concentration, s/cc} = \frac{\#\text{ Asbestos Structures}}{\#\text{ GO Counted}} \times \frac{1}{\text{Volume (L)}} \times \frac{\text{Eff. Filter Area } (mm^2)}{\text{Average GO area } (mm^2)} \times \frac{1\text{L}}{1000\text{cc}}$$

$$\text{Filter loading, s/mm}^2 = \frac{\#\text{ Asbestos structures}}{\text{Area Analyzed } (mm^2)}$$

GO = TEM grid opening

Reservoirs Environmentol, Inc.

February 24, 2012

Laboratory Code:	RES
Subcontract Number:	NA
Laboratory Report:	RES 230328-1
Project # / P.O. #	None Given
Project Description:	3rd West Sub - RMP

Eldon Romney
R & R Environmental
47 West 9000 South #2
Sandy UT 84070

Dear Customer,

Reservoirs Environmental, Inc. is an analytical laboratory accredited for the analysis of Industrial Hygiene and Environmental matrices by the National Voluntary Laboratory Accreditation Program (NVLAP), Lab Code 101896-0 for Transmission Electron Microscopy (TEM) and Polarized Light Microscopy (PLM) analysis and the American Industrial Hygiene Association (AIHA), Lab ID 101533 - Accreditation Certificate #480 for Phase Contrast Microscopy (PCM) analysis. This laboratory is currently proficient in both Proficiency Testing and PAT programs respectively.

Reservoirs Environmental, Inc. has analyzed the following samples for asbestos content as per your request. The analysis has been completed in general accordance with the appropriate methodology as stated in the attached analysis table. The results have been submitted to your office.

RES 230328-1 is the job number assigned to this study. This report is considered highly confidential and the sole property of the customer. Reservoirs Environmental, Inc. will not discuss any part of this study with personnel other than those of the client. The results described in this report only apply to the samples analyzed. This report must not be used to claim endorsement of products or analytical results by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without written approval from Reservoirs Environmental, Inc. Samples will be disposed of after sixty days unless longer storage is requested. If you have any questions about this report, please feel free to call 303-964-1986.

Sincerely,



Jeanne Spencer Orr
President

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE I. TEM AIR FILTER SAMPLE DATA AND ANALYTICAL RESULTS

RES Job Number:	RES 230328-1
Client:	R & R Environmental
Client Project Number / P.O.:	None Given
Client Project Description:	3rd West Sub - RMP
Date Samples Received:	February 23, 2012
Analysis Type:	TEM, AHERA
Turnaround:	24 Hour
Date Samples Analyzed:	February 24, 2012

Client ID Number	Lab ID Number	Area Analyzed	Air Volume Sampled	Number of Asbestos Structures Detected	Analytical Sensitivity	Asbestos Concentration	Filter Loading
		(mm^2)	(L)		(s/cc)	(s/cc)	(s/mm^2)
3W-022212 W	EM 867882	0.0900	930	ND	0.0046	BAS	BAS
3W-022212 N	EM 867883	0.0900	930	ND	0.0046	BAS	BAS
3W-022212 E	EM 867884	0.1000	827	ND	0.0047	BAS	BAS
3W-022212 S	EM 867885	0.0900	927	ND	0.0046	BAS	BAS

NA = Not Analyzed
ND = None Detected
BAS = Below Analytical Sensitivity
Average Grid Opening in mm^2 = 0.010

Filter Material = Mixed Cellulose Ester
Filter Diameter = 25 mm
Effective Filter Area = 385 sq mm

DATA QA

RES 230328

Due Date: 2-24-12
Due Time: 900a

Reservoirs Environmental, Inc.

REI LAB
8601 Logm St Denver, CO 80216 • Ph: 303 654-1966 • Fax 303-477-4275 • Toll Free :866 RESI-ENV
Pager : 303-899-8098

Page 1 of 1

INVOICE TO: (IF DIFFERENT)		CONTACT INFORMATION:	
Company: R & R Environmental	Company:	Contact: Dave Roskelley	Contact:
Address: 47 W 9000S #2 Sandy Ut. 84070	Address:	Phone:	Phone:
		Fax:	Fax:
		Cell/pager:	Cell/pager:
Project Number and/or P.O. #:		Final Data Deliverable Email Address:	
Project Description/Location: 30" West Sub-RMP		801 541-1035	

ASBESTOS LABORATORY HOURS: Weekdays: 7am - 7pin
PLM / PCM / (TEM) ___ RUSH (Same Day) X PRIORITY (Next Day) ___ STANDARD
(Rush PCM = 2hr, TEM = 6hr.)

CHEMISTRY LABORATORY HOURS: Weekdays: 8am - 5pm
Metal(s) / Dust ___ RUSH ___ 24 hr. ___ 3-5 Day
RCRA 8 / Metals S Welding Fume Scan / TCLP ___ RUSH ___ 5 day ___ 10 day
Organics ___ 24 hr. ___ 3 day ___ 5 Day
Prior notification is required for RUSH turnarounds.

MICROBIOLOGY LABORATORY HOURS: Weekdays: 9am - 6pin
E.coli 0157:H7, Coliforms, S.aureus ___ 24 hr. ___ 2 Day ___ 3-5 Day
Salmonella, Listeria, E.coli, APC, Y & M ___ 48 Hr. ___ 3-5 Day
Mold ___ RUSH ___ 24 Hr ___ 48 Hr ___ 3 Day ___ 5 Day

Turnaround times establish a laboratory priority, subject to laboratory volume and are not guaranteed. Additional fees apply for afterhours, weekends and holidays.

Special Instructions:

REQUESTED ANALYSIS

Client sample ID number (Sample ID's must be unique)	PLM - Short report, Long report, Point Count	TEM - AHERA, Level II, 7402, ISO, +/-, Quant, Semi-quant, Micro-vac, ISO-Indirect Preps	PCM - 7400A, 7400B, OSHA	DUST - Total, Respirable	METALS - Analyte(s) RCRA 8, TCLP, Welding Fume, Metals Scan	ORGANICS - METH	MICROBIOLOGY: Salmonella: +/-	MICROBIOLOGY: E.coli 0157:H7: +/-	MICROBIOLOGY: Listeria: +/-	MICROBIOLOGY: Aerobic Plate Count: +/- or Quantification	MICROBIOLOGY: E.coli: +/- or Quantification	MICROBIOLOGY: Coliforms: +/- or Quantification	MICROBIOLOGY: S.aureus: +/- or Quantification	MICROBIOLOGY: Y & M: +/- or Quantification	MICROBIOLOGY: Mold: +/-, Identification, Quantification	SAMPLER'S INITIALS OR OTHER NOTES	Sample Volume (L) / Area	Matrix Code	# Containers	Date Collected mm/dd/yy	Time Collected hh/mm a/p	EM Number (Laboratory Use Only)
1 3W-022212 W		X															930	A		2/22/12		867882
2 3W-022212 N		↓															930	↓		↓		83
3 3W-022212 E																	827					84
4 3W-022212 S																	927					85
5																						
6																						
7																						
8																						
9																						
10																						

VALID MATRIX CODES

Air = A	Bulk = B
Dust = D	Paint = P
Soil = S	Wipe = W
Swab = SW	F = Food
Drinking Water = DW	Waste Water = WW
O = Other	

ASTM 61792 approved wipe media only

LAB NOTES:

Number of samples received: 4 (Additional samples shall be listed on attached long form.)

NOTE: REI will analyze incoming samples based upon information received and will not be responsible for errors or omissions in calculations resulting from the inaccuracy of original data. By signing client/company representative agrees that submission of the following samples for requested analysis as indicated on this Chain of Custody shall constitute an analytical services agreement with payment terms of NET 30 days, failure to comply with payment terms may result in a 1.5% monthly interest surcharge.

Relinquished By: [signature] Fed Ex Date/Time: 2/22/12

Laboratory Use Only
Received By: [signature] Date/Time: 2/22/12 @ 905a Carrier: FedEx

Sample Condition: Temp. (F°) ____ On Ice Yes / No Sealed Yes / No Intact (Yes) / No

Results:	Contact	Phone	Email	Fax	Date	Time	Initials	Contact	Phone	Email	Fax	Date	Time	Initials
	Contact	Phone	Email	Fax	Date	Time	Initials	Contact	Phone	Email	Fax	Date	Time	Initials

Financial #: 79660 5514 10414

Attachment I

Key to Count Sheets
Count Sheets
Analytical Procedures

Structures identifications consist of an Asbestos Type followed by a Structure Type

Asbestos Type	Structure Types
A = Amosite	F = Fiber
An = Anthophyllite	B = Bundle
C = Chrysotile	C = Cluster
Cr = Crocidolite	M = Matrix
T = Tremolite	

ND = no structures detected
M = other structure associated with a matrix
NAM = Non Asbestos Mineral
XGB = partly obscured by a grid bar

Sizing Conversion
1 length unit = 5 mm on screen = 0.278 micron
1.80 length units = 0.5 micron
18.0 length units = 5 microns

1 width unit = 1 mm on screen = 0.0556 micron

TEM Analysts

Jeanne S. Orr
Nathan DelHierro
Angela Heitger
Jonathan Bernard
Paul D. LoScalzo
Mark Steiner
Norberto Zimbleman
Robert Workman



Upper and lower 95% confidence bounds for the number of structures counted assuming a Poisson distribution.

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R&R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	930
Date received by lab	2/23/12
Lab Job Number	230328
Lab Sample Number	867882

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	G3-4	ND												
	F3-4	ND					Prep A	80% structure		5% debris				
	E3-4	ND					Prep B	50% structure		5% debris				
	F5-1	ND												
	E5-1	ND												
B	G5-3	ND					AB	2/24/12						
	F5-3	ND												
	E5-3	ND												
	C5-1	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory nama:	REI
Instrument	JEOL 100 CX (N) S
Vollage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 10 =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Tyoe	

Client :	R&R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	930
Date received by lab	2/23/12
Lab Job Number:	230328
Lab Sample Numben	8678843

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indircct, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	G3-6	ND												
	F3-6	ND				Pump A		80% amphi			5% debris			
	E3-6	ND				Pump B		60% amphi			5% debris			
	C3-6	ND												
	B3-6	ND									2/24/12			
B	H3-1	ND												
	G3-1	ND												
	F2-3	ND												
	E2-3	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	20KX - 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R&K
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	829
Date received by lab	2/23/12
Lab Job Number:	230328
Lab Sample Number:	867884

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	H2-6	ND												
	G2-6	ND					Pmp A	80% tremolite			5% debris			
	F2-6	ND					Pmp B	70% tremolite			5% debris			
	E2-6	ND												
	F3-6	ND						JB		2/24/12				
B	H3-4	ND												
	G3-4	ND												
	G2-1	ND												
	F2-1	ND												
	E2-1	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (II) S
Voltage (KV)	100 KV
Magnification	20KX 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	RJH
Sample Tyoe (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	927
Date received by lab	2/23/12
Lab Job Numben	230328
Lab Sample Number:	867885

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Stmctures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	H3-4	ND												
	G3-4	ND					Prep A	80% in fmf			5-10% debris			
	F3-4	ND					Prep B	50% in fmf			5-10% debris			
	E3-4	ND												
	C3-4	ND												
B	L5-1	ND							JB	2/24/12				
	K5-1	ND												
	H5-1	ND												
	G5-1	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Analytical Procedures – AHERA

Transmission electron microscopy/energy dispersive X-ray spectrometry/selected area electron diffraction (TEM/EDX/SAED) was employed in the analysis of the samples, which were collected on 25 mm mixed cellulose ester air filters. A portion of each filter was collapsed with acetone and etched in a plasma asher. The etched filter was then coated with a thin layer of carbon in a carbon side down. The sample was then placed inside a condensation washer and treated with acetone to remove the filter matrix and expose any inert material.

For each sample, enough grid openings on a 200 mesh TEM grid are analyzed to ensure an analytical sensitivity of at least 0.005 structures/cc. A minimum of four grid openings from two preparations are analyzed for each sample. The grid openings are searched for fibrous structures which, if present are analyzed by SAED and/or EDX (elemental analysis). The AHERA protocol requires SAED confirmation of enough chrysotile asbestos structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures). Both SAED and EDX confirmation are required of enough amphibole structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures) per sample. Either SAED or EDX is required for the remaining asbestos structures of either type. The morphology of each structure is determined and the length and the diameter of any asbestos structures are recorded. Asbestos fibers, bundles, cluster and matrices were identified and recorded. The asbestos structures have been defined in AHERA as follows:

Fiber:	is a structure having a minimum length greater than or equal to 0.5 micron with an aspect ratio of 5:1 or greater with substantially parallel sides.
Bundle:	is a structure composed of three or more fibers in parallel arrangement, with each fiber closer than the diameter of one fiber.
Cluster:	is a structure with fibers in random arrangements such that all fibers are intermixed and no single fiber is isolated from the group.
Matrix:	is a fiber or fibers with one end free and the other end embedded or hidden by a particulate. The exposed fiber end must meet the fiber definition given above.

If more than 50 asbestos structures are identified and confirmed on a sample, AHERA analysis may be terminated after completion of the grid opening, which contains the 50th structure. AHERA protocol requires the laboratory to reject any clearance sample which contains in excess of 25% total particulate loading or which appears to be unevenly loaded.

The AHERA protocol includes specific sampling requirements, including minimum numbers of samples and minimum air volumes. Specifically, the 70 structures/mm^2 clearance criteria is only allowed for sets five inside samples (collected in a group of 13 samples including: five outsides and three blanks) with volumes greater than 1200 liters (40 CFR Part 763, page 41894). Deviation from the AHERA sampling protocol may affect the validity of the analytical results. Analysis of samples collected by non-protocol methods are not accredited by NVLAP

Equations Used for Calculations

$$\text{Area Analyzed, mm}^2 = \#\text{ GO counted} \times \text{Average GO Area (mm)}$$

$$\text{Concentration, s/cc} = \frac{\#\text{ Asbestos Structures}}{\#\text{ GO Counted}} \times \frac{1}{\text{Volume (L)}} \times \frac{\text{Eff. Filter Area (mm}^2)}{\text{Average GO area (mm}^2)} \times \frac{1\text{L}}{1000\text{cc}}$$

$$\text{Filter loading, s/mm}^2 = \frac{\#\text{ Asbestos structures}}{\text{Area Analyzed (mm}^2)}$$

GO = TEM grid opening

File: Shared on server T/Offforms.sg/AHERA Procedures
Revised: 02/27/02

REI LAB Reservoirs Environmentol, Inc.

February 27, 2012

Laboratory Code:	RES
Subcontract Numben	NA
Laboratory Report:	RES 230398-1
Project # / P.O. #	None Given
Project Description:	3rd West Sub - RMP

David Roskelley
R & R Environmental
47 West 9000 South #2
Sandy UT 84070

Dear Customer,

Reservoirs Environmental, Inc. is an analytical laboratory accredited for the analysis of Industrial Hygiene and Environmental matrices by the National Voluntary Laboratory Accreditation Program (NVLAP), Lab Code 101896-0 for Transmission Electron Microscopy (TEM) and Polarized Light Microscopy (PLM) analysis and the American Industrial Hygiene Association (AIHA), Lab ID 101533 - Accreditation Certificate #480 for Phase Contrast Microscopy (PCM) analysis. This laboratory Is currently proficient in both Proficiency Testing and PAT programs respectively.

Reservoirs Environmental, Inc. has analyzed the following samples for asbestos content as per your request. The analysis has been completed In general accordance with the appropriate methodology as stated in the attached analysis table. The results have been submitted to your office.

RES 230398-1 is the job number assigned to this study. This report is considered highly confidential and the sole property of the customer. Reservoirs Environmental, Inc. will not discuss any part of this study with personnel other than those of the client. The results described In this report only apply to the samples analyzed. This report must not be used to claim endorsement of products or analytical results by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without written approval from Reservoirs Environmental, Inc. Samples will be disposed of after sixty days unless longer storage is requested. If you have any questions about this report, please feel free to call 303-964-1986.

Sincerely,



Jeanne Spencer Orr
President

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE I. TEM AIR FILTER SAMPLE DATA AND ANALYTICAL RESULTS

RES Job Number:	RES 230398-1
Client:	R & R Environmental
Client Project Number / P.O.:	None Given
Client Project Description:	3rd West Sub - RMP
Date Samples Received:	February 24, 2012
Analysis Type:	TEM, AHERA
Turnaround:	24 Hour
Date Samples Analyzed:	February 24, 2012

Client ID Number	Lab ID Number	Area Analyzed	Air Volume Sampled	Number of Asbestos Structures Detected	Analytical Sensitivity	Asbestos Concentration	Filter Loading
		(mm^2)	(L)		(s/cc)	(s/cc)	(s/mm^2)
3W-022312 W	EM 868464	0.0800	968	ND	0.0050	BAS	BAS
3W-022312 N	EM 868465	0.0800	968	ND	0.0050	BAS	BAS
3W-022312 E	EM 868466	0.0800	970	1	0.0050	0.0050	12.5
3W-022312 S	EM 868467	0.0900	961	ND	0.0045	BAS	BAS

NA = Not Analyzed
ND = None Detected
BAS = Below Analytical Sensitivity
Average Grid Opening in mm^2 = 0.010

Filter Material = Mixed Cellulose Ester
Filter Diameter = 25 mm
Effective Filter Area = 385 sq mm

DATA QA

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE II. SUMMARY OF ANALYTICAL DATA

RES Job Number: RES 230398-1
Client: R & R Environmental
Client Project Number / P.O.: None Given
Client Project Description: 3rd West Sub - RMP
Date Samples Received: February 24, 2012
Analysis Type: TEM, AHERA
Turnaround: 24 Hour
Date Samples Analyzed: February 24, 2012

Client ID Number	Lab ID Number	Asbestos Mineral	Asbestos Structure Types*				Structures >5 Microns in Lengtb	**Excluded Structures	Asbestos Structures for Concentration
			Fibers	Bundles	Clusters	Matrices			
3W-022312 W	EM 868464	ND	0	0	0	0	0	0	0
3W-022312 N	EM 868465	ND	0	0	0	0	0	0	0
3W-022312 E	EM 868466	Cbrysotile	1	0	0	0	0	0	1
3W-022312 S	EM 868467	ND	0	0	0	0	0	0	0

*See Analytical Procedure for definitions
**C = Excluded from total due to lack of confirmation
**L = Excluded from total for length less than 0.5 micron (AHERA only)
**A = Excluded from total due to incorrect aspect ratio
ND = None Detected

RES 230398

Due Date: 2-25-12
Due Time: 9Sam

Reservnirs Environmental, Inc.

5601 Logan St. Denver, CO 80216 • Ph: 303 964-1999 • Fax 303-477-4275 • Toll Free :866 RESI-ENV
Pager : 303-609-2098

Page 1 of 1

INVOICE TO: (IF DIFFERENT)

Company: R&R Environmental	Company:
Address: 47W 9000S #2 Sandy Ut. 84070	Address:
Project Number and/or P.O. #:	
Project Description/Location: 3rd West Sub - RMP	

CONTACT INFORMATION:

Contact: Dave Roskelley	Contact
Phone:	Phone:
Fax:	Fax:
Cell/pager: 801 541-1035	Cell/pager:
Final Data Deliverable Email Address: dave@rmenviro.com	

ASBESTOS LABORATORY HOURS: Weekdays: 7am - 7pm
PLM / PCM / TEM ___ RUSH (Same Day) X PRIORITY (Next Day) ___STANDARD
(Rush PCM = 2hr, TEM = 6hr.)

CHEMISTRY LABORATORY HOURS: Weekdays: 8am - 5pm
Metal(s) / Dust ___ RUSH ___ 24 hr. ___3-5 Day
RCRA B / Metals & Welding Fume Scan / TCLP ___ RUSH ___ 5 day ___ 10 day
Organics ___ 24 hr. ___ 3 day ___ 5 Day
Prior notification is required for RUSH turnarounds.

MICROBIOLOGY LABORATORY HOURS: Weekdays: 9am - 6pm
E.coli O157:H7, Coliforms, S.aureus ___ 24 hr. ___2 Day ___3-5 Day
Salmonella, Listeria, E.coli, APC, Y & M ___ 48 Hr. ___3-5 Day
Mold ___ RUSH ___24 Hr ___48 Hr ___3 Day ___5 Day

Turnaround times establish a laboratory priority, subject to laboratory voluma and are not guaranteed. Additional fees apply for after-houre, weekends and holidays.

Special Instructions:

REQUESTED ANALYSIS

Client sample ID number (Sample ID's must be unique)	PLM - Short report, Long report, Point Count	TEM - AHERA, Level II, 7402, ISO, +/-, Quant, Semi-quant, Micro-vac, ISO-Indirect Preps	PCM - 7400A, 7400B, OSHA	DUST - Total, Respirable	METALS - Analyte(s) RCRA 8, TCLP, Welding Fume, Metals Scan	ORGANICS - METH	MICROBIOLOGY: Salmonella: +/-	E.coli O157:H7: +/-	Listeria: +/-	Aerobic Plate Count: +/- or Quantification	E.coli: +/- or Quantification	Coliforms: +/- or Quantification	S.aureus: +/- or Quantification	Y & M: +/- or Quantification	Mold: +/-, Identification, Quantification	SAMPLER'S INITIALS OR OTHER NOTES	Sample Volume (L) / Area	Matrix Code	# Containers	Date Collected mm/dd/yy	Time Collected hh/mm a/p	EM Number (Laboratory Use Only)
1 3W-022312W		X															968	A		2/23/12		66364
2 3W-022312N		↓															968	↓		↓		65
3 3W-022312E																	970					66
4 3W-022312S																	961					67
5																						
6																						
7																						
8																						
9																						
10																						

VALID MATRIX CODES

Air = A	Bulk = B
Dust = D	Paint = P
Soil = S	Wipe = W
Swab = SW	F = Food
Drinking Water = DW	Waste Water = WW
O = Other	

ASTM E1792 aproved wipe media only

LAB NOTES:

Number of samples received: 4 (Additional samples shall be listed on attached long form.)

NOTE: REI will analyze incoming samples based upon information received and will not be responsible for errors or omissions in calculations resulting from the inaccuracy of original data. By signing client/company representative agrees that notification of the following samples for requested analysis as indicated on this Chain of Custody shall constitute an analytical services agreement with payment terms of NET 30 days. failure to comply with payment terms may result in a 1.5% monthly interest surcharge.

Relinquished By: [signature] Fed Ex Date/Time: 2/23/12
Laboratory Use Only
Received By: [signature] Date/Time: 2/24 @ 9Sam Carrier FedEx

Sample Condition: On Ice: Yes / No Sealed: Yes / No Intact: (Yes) / No
Temp. (F°) _____

Results: Contact Dave Phone Email Fax Date 2/24 Time 10:15 Initials [initials]
Left msg
Contact Phone Email Fax Date Time Initials
Hawley #: 7502 C522 2237

Contact Phone Email Fax Date 2/27/12 Time 9Sam Initials [initials]
Contact Phone Email Fax Date Time Initials

Attachment I

Key to Count Sheets
Count Sheets
Analytical Procedures

Structures identifications consist of an Asbestos Type followed by a Structure Type

Asbestos Type	Structure Types
A = Amosite	F = Fiber
An = Anthophyllite	B = Bundle
C = Chrysotile	C = Cluster
Cr = Crocidolite	M = Matrix
T = Tremolite	

ND = no structures detected
M = other structure associated with a matrix
NAM = Non Asbestos Mineral
XGB = partly obscured by a grid bar

Sizing Conversion
1 length unit = 5 mm on screen = 0.278 micron
1.80 length units = 0.5 micron
18.0 length units = 5 microns

1 width unit = 1 mm on screen = 0.0556 micron

TEM Analysts

Jeanne S. Orr
Nathan DelHierro
Angela Heitger
Jonathan Bernard
Paul D. LoScalzo
Mark Steiner
Norberto Zimbleman
Robert Workman



Upper and lower 95% confidence bounds for the number of structures counted assuming a Poisson distribution.

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX N S
Voltage (KV)	100 KV
Magnification	20KX 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	386
Secondary Filter Area (mm2)	
QA Type	

Client :	PSR
Sample Tyoe (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	968
Date received by lab	2/24/12
Lab Job Number:	230398
Lab Sample Number:	668462 3 4

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Voturns (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JK
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Lenoth	Width		Amphibole	C	NAM		Sketch	Photo	EOS
A	H6-4	ND												
	F6-4	ND				Prep	A 7%	(Mass 5-7%			debris			
	E6-4	ND				Prep	Brit	Complete 2/24/12						
	C6-4	ND												
B	H6-6	ND												
	G6-6	ND												
	F6-6	ND												
	E6-6	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysolile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
***TEM* Asbestos *Structure* Count**

Laboratory name:	REI
Instrument	JEOL 100 CX N S
Voltage (KV)	100 KV
Magnification	20KX 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Tyoe	

Client :	R+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	968
Date received by lab	2/24/12
Lab Job Number	230398
Lab Sample Number	8684 TH 2/24 6 A5

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	TK
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AHH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	G5-6	ND												
	F5-6	ND				Prep	A 90%	intact 3-5% debris						
	E5-6	ND				Prep	B nA	Grid 2/24/12						
	C5-6	ND												
B	H4-6	ND												
	G4-6	ND												
	F4-6	ND												
	C5-4	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX N S (S circled)
Voltage (KV)	100 KV
Magnification	20KX (crossed out) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	770
Date received by lab	2/24/12
Lab Job Number:	230398
Lab Sample Number:	868466

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	[illegible]
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures: Primary	No. of Structures: Total	Dimensions: Length	Dimensions: Width	Identification	Mineral Class: Amphibole	Mineral Class: C	Mineral Class: NAM	Sketch/Comments	1 = yes, blank = no: Sketch	Photo	EDS
A	F3-6	ND												
	E3-6	ND			Prep A 80% intact ~5% debris									
	C3-6	ND			Prep B ~A			[illegible signature] 2/24/12						
	B3-6	ND												
B	G5-3	ND												
	F5-3	ND												
	E5-3	F		1	9.5	1	CD		/		\			
	C5-3	ND												

LA = Libby-type amphibole   OA = Other (non-Libby type) amphibole   C = Chrysotile   NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX N
Voltage (KV)	100 KV
Magnification	20KX 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	961
Date received by lab	2/24/12
Lab Job Number:	230398
Lab Sample Number:	868467

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	MK
Analysis date	2/24/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	G4-4	ND												
	F4-4	ND				Prep A	90%	intact	~5%	debris				
	E4-4	ND				Prep B	NA	Amph	2/24/12					
	E4-6	ND												
	C4-6	ND												
B	H4-4	ND												
	G4-4	ND												
	F4-4	ND												
	E4-4	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Analytical Procedures – AHERA

Transmission electron microscopy/energy dispersive X-ray spectrometry/selected area electron diffraction (TEM/EDX/SAED) was employed in the analysis of the samples, which were collected on 25 mm mixed cellulose ester air filters. A portion of each filter was collapsed with acetone and etched in a plasma asher. The etched filter was then coated with a thin layer of carbon in a carbon side down. The sample was then placed inside a condensation washer and treated with acetone to remove the filter matrix and expose any inert material.

For each sample, enough grid openings on a 200 mesh TEM grid are analyzed to ensure an analytical sensitivity of at least 0.005 structures/cc. A minimum of four grid openings from two preparations are analyzed for each sample. The grid openings are searched for fibrous structures which, if present are analyzed by SAED and/or EDX (elemental analysis). The AHERA protocol requires SAED confirmation of enough chrysotile asbestos structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures). Both SAED and EDX confirmation are required of enough amphibole structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures) per sample. Either SAED or EDX is required for the remaining asbestos structures of either type. The morphology of each structure is determined and the length and the diameter of any asbestos structures are recorded. Asbestos fibers, bundles, cluster and matrices were identified and recorded. The asbestos structures have been defined in AHERA as follows:

Fiber:	is a structure having a minimum length greater than or equal to 0.5 micron with an aspect ratio of 5:1 or greater with substantially parallel sides.
Bundle:	is a structure composed of three or more fibers in parallel arrangement, with each fiber closer than the diameter of one fiber.
Cluster:	is a structure with fibers in random arrangements such that all fibers are intermixed and no single fiber is isolated from the group.
Matrix:	is a fiber or fibers with one end free and the other end embedded or hidden by a particulate. The exposed fiber end must meet the fiber definition given above.

If more than 50 asbestos structures are identified and confirmed on a sample, AHERA analysis may be terminated after completion of the grid opening, which contains the 50^{th} structure. AHERA protocol requires the laboratory to reject any clearance sample which contains in excess of 25% total particulate loading or which appears to be unevenly loaded.

The AHERA protocol includes specific sampling requirements, including minimum numbers of samples and minimum air volumes. Specifically, the 70 structures/mm^2 clearance criteria is only allowed for sets five inside samples (collected in a group of 13 samples including: five outsides and three blanks) with volumes greater than 1200 liters (40 CFR Part 763, page 41894). Deviation from the AHERA sampling protocol may affect the validity of the analytical results. Analysis of samples collected by non-protocol methods are not accredited by NVLAP

Equations Used for Calculations

$$\text{Area Analyzed, } mm^2 = \#\text{ GO counted} \times \text{Average GO Area (mm)}$$

$$\text{Concentration, s/cc} = \frac{\#\text{ Asbestos Structures}}{\#\text{ GO Counted}} \times \frac{1}{\text{Volume (L)}} \times \frac{\text{Eff. Filter Area } (mm^2)}{\text{Average GO area } (mm^2)} \times \frac{1\text{L}}{1000\text{cc}}$$

$$\text{Filter loading, s/mm}^2 = \frac{\#\text{ Asbestos structures}}{\text{Area Analyzed } (mm^2)}$$

GO = TEM grid opening

REI LAB Reservoirs Environmentol, Inc.

February 28, 2012

Laboratory Code:	RES
Subcontract Number:	NA
Laboratory Report:	RES 230511-1
Project # / P.O. #	None Given
Project Description:	3rd West Sub - RMP

David Roskelley
R & R Environmental
47 West 9000 South #2
Sandy UT 84070

Dear Customer,

Reservoirs Environmental, Inc. is an analytical laboratory accredited for the analysis of Industrial Hygiene and Environmental matrices by the National Voluntary Laboratory Accreditation Program (NVLAP), Lab Code 101896-0 for Transmission Electron Microscopy (TEM) and Polarized Light Microscopy (PLM) analysis and the American Industrial Hygiene Association (AIHA), Lab ID 101533 - Accreditation Certificate #480 for Phase Contrast Microscopy (PCM) analysis. This laboratory Is currently proficient in both Proficiency Testing and PAT programs respectively.

Reservoirs Environmental, Inc. has analyzed the following samples for asbestos content as per your request. The analysis has been completed in general accordance with the appropriate methodology as stated in the attached analysis table. The results have been submitted to your office.

RES 230511-1 Is the job number assigned to this study. This report Is considered highly confidential and the sole property of the customer. Reservoirs Environmental, Inc. will not discuss any part of this study with personnel other than those of the client. The results described In this report only apply to the samples analyzed. This report must not be used to claim endorsement of products or analytical results by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except In full, without written approval from Reservoirs Environmental, Inc. Samples will be disposed of after sixty days unless longer storage is requested. If you have any questions about this report, please feel free to call 303-964-1986.

Sincerely,

Jeanne Spencer Orr
President

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE I. TEM AIR FILTER SAMPLE DATA AND ANALYTICAL RESULTS

RES Job Number:	RES 230511-1
Client:	R & R Environmental
Client Project Number / P.O.:	None Given
Client Project Description:	3rd West Sub - RMP
Date Samples Received:	February 27, 2012
Analysis Type:	TEM, AHERA
Turnaround:	24 Hour
Date Samples Analyzed:	February 28, 2012

Client ID Number	Lab ID Number	Area Analyzed	Air Volume Sampled	Number of Asbestos Structures Detected	Analytical Sensitivity	Asbestos Concentration	Filter Loading
		(mm^2)	(L)		(s/cc)	(s/cc)	(s/mm^2)
3W-022412 W	EM 869219	0.0900	889	ND	0.0048	BAS	BAS
3W-022412 N	EM 869220	0.0900	894	ND	0.0048	BAS	BAS
3W-022412 E	EM 869221	0.0900	893	ND	0.0048	BAS	BAS
3W-022412 S	EM 869222	0.0900	889	ND	0.0048	BAS	BAS

NA = Not Analyzed
ND = None Detected
BAS = Below Analytical Sensitivity
Average Grid Opening in mm^2 = 0.010

Filter Material = Mixed Cellulose Ester
Filter Diameter = 25 mm
Effective Filter Area = 385 sq mm

Digitally signed by Elisha Ellerman
DN: CN = Elisha Ellerman, C = US, O = Reservoirs Environmental, Inc.
Date: 2012.02.28 10:57:44 -07'00'

DATA QA

RESERVOIRS ENVIRONMENTAL, INC.

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE II. SUMMARY OF ANALYTICAL DATA

RES Job Number: RES 230511-1
Client: R & R Environmental
Client Project Number / P.O.: None Given
Client Project Description: 3rd West Sub - RMP
Date Samples Received: February 27, 2012
Analysis Type: TEM, AHERA
Turnaround: 24 Hour
Date Samples Analyzed: February 28, 2012

Client ID Number	Lab ID Number	Asbestos Mineral	Asbestos Structure Types*				Structures >5 Microns in Length	**Excluded Structures	Asbestos Structures for Concentration
			Fibers	Bundles	Clusters	Matrices			
3W-022412 W	EM 869219	ND	0	0	0	0	0	0	0
3W-022412 N	EM 869220	ND	0	0	0	0	0	0	0
3W-022412 E	EM 869221	ND	0	0	0	0	0	0	0
3W-022412 S	EM 869222	ND	0	0	0	0	0	0	0

*See Analytical Procedure for definitions
**C = Excluded from total due to lack of confirmation
**L = Excluded from total for length less than 0.5 micron (AHERA only)
**A = Excluded from total due to incorrect aspect ratio
ND = None Detected

RES 230511

Due Date: 2·28·12
Due Time: 10a

Reservnirs Environmental, Inc.

5601 Logan St. Denver, CO 80216 • Ph: 303 964-1988 • Fax 303-477-4275 • Toll Free :866 RESI-ENV
Pager : 303-609-3098

Page 1 of

INVOICE TO: (IF DIFFERENT)

Company: R&R Environmental	Company:
Address: 47 W 9000S #2 Sandy Ut. 84070	Address:
Project Number and/or P.O. #:	
Project Description/Location: 3rd West Sub- RMP	

CONTACT INFORMATION:

Contact: Dave Roskelley	Contact:
Phone:	Phone:
Fax:	Fax:
Cell/pager: 801 541-1035	Cell/pager:
Final Data Deliverable Email Address: dave@rrenviro.com	

ASBESTOS LABORATORY HOURS: Weekdays: 7am - 7pm

PLM / PCM / (TEM) ___ RUSH (Same Day) X PRIORITY (Next Day) ___ STANDARD
(Rush PCM = 2hr, TEM = 6hr.)

CHEMISTRY LABORATORY HOURS: Weekdays: 8am - 5pm

Metal(s) / Dust ___ RUSH ___ 24 hr. ___ 3-5 Day
RCRA 8 / Metals S Welding Fume Scan / TCLP ___ RUSH ___ 5 day ___ 10 day
Organics ___ 24 hr. ___ 3 day ___ 5 Day

Prior notification is required for RUSH turnarounds.

MICROBIOLOGY LABORATORY HOURS: Weekdays: 9am - 6pm

E.coli O157:H7, Coliforms, S.aureus ___ 24 hr. ___ 2 Day ___ 3-5 Day
Salmonella, Listeria, E.coli, APC, Y & M ___ 48 Hr. ___ 3-5 Day
Mold ___ RUSH ___ 24 Hr ___ 48 Hr ___ 3 Day ___ S Day

Turnaround times establish a laboratory priority, subject to laboratory volume and are not guaranteed. Additional fees apply for afterhours, weekends and holidays.

Special Instructions:

REQUESTED ANALYSIS

Client sample ID number (Sample ID's must be unique)	PLM - Short report, Long report, Point Count	TEM - AHERA, Level II, 7402, ISO, +/-, Quant, Semi-quant, Micro-vac, ISO-Indirect Preps	PCM - 7400A, 7400B, OSHA	DUST - Total, Respirable	METALS - Analyte(s) RCRA 8, TCLP, Welding Fume, Metals Scan	ORGANICS - METH	MICROBIOLOGY: Salmonella: +/-	E.coli O157:H7: +/-	Listeria: +/-	Aerobic Plate Count: +/- or Quantification	E.coli: +/- or Quantification	Coliforms: +/- or Quantification	S.aureus: +/- or Quantification	Y & M: +/- or Quantification	Mold: +/-, Identification, Quantification	SAMPLER'S INITIALS OR OTHER NOTES	Sample Volume (L) / Area	Matrix Code	# Containers	Date Collected mm/dd/yy	Time Collected hh/mm a/p	EM Number (Laboratory Use Only)
1 3W-022412W		X															839	A		2/24/12		869219
2 3W-022412N		↓															894	↓		↓		20
3 3W-022412E																	893					21
4 3W-022412S																	889					22
5																						
6																						
7																						
8																						
9																						
10																						

VALID MATRIX CODES

Air = A	Bulk = B
Dust = D	Paint = P
Soil = S	Wipe = W
Swab = SW	F = Food
Drinking Water = DW	Waste Water = WW
O = Other	

ASTM E1792 approved wipe media only

LAB NOTES:

Number of samples received: 4 (Additional samples shall be listed on attached long form.)

NOTE: REI will analyze incoming samples based upon information received and will not be responsible for errors or omissions in calculations resulting from the inaccuracy of original data. By signing client/company representative agrees that submission of the following samples for requested analysis as indicated on this Chain of Custody shall constitute an analytical services agreement with payment terms of NET 30 days, failure to comply with payment terms may result in a 1.5% monthly interest surcharge.

Relinquished By: [signature] FedEx Date/Time: 2/24/12

Laboratory Use Only
Received By: [signature] Date/Time: 2·27·12 10a Carrier: FedEx

Sample Condition: On Ice Yes / No Sealed Yes / No Intact (Yes) / No
Temp. (F°) ____

Results:												
Contact	Phone Email Fax	Date	Time	Initials	Contact	Phone Email Fax	Date	Time	Initials
Contact	Phone Email Fax	Date	Time	Initials	Contact	Phone Email Fax	Date	Time	Initials

7932 6522 7089

7-2011_version 1

Attachment I

Key to Count Sheets
Count Sheets
Analytical Procedures

Structures identifications consist of an Asbestos Type followed by a Structure Type

Asbestos Type	Structure Types
A = Amosite	F = Fiber
An = Anthophyllite	B = Bundle
C = Chrysotile	C = Cluster
Cr = Crocidolite	M = Matrix
T = Tremolite	

ND = no structures detected
M = other structure associated with a matrix
NAM = Non Asbestos Mineral
XGB = partly obscured by a grid bar

Sizing Conversion
1 length unit = 5 mm on screen = 0.278 micron
1.80 length units = 0.5 micron
18.0 length units = 5 microns

1 width unit = 1 mm on screen = 0.0556 micron

TEM Analysts

Jeanne S. Orr	Paul D. LoScalzo
Nathan DelHierro	Mark Steiner
Angela Heitger	Norberto Zimbleman
Jonathan Bernard	Robert Workman



Upper and lower 95% confidence bounds for the number of structures counted assuming a Poisson distribution.

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R&R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	859
Date received by lab	2/27/12
Lab Job Number:	230511
Lab Sample Number:	86921 9

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/28/12
Method (D=Direct, I=Indirect, IA=Indirect, astied)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Moith Arialyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	H4-1	ND												
	G4-1	ND												
	F4-1	ND			Pkgs		A+B	~60% content			3-Structures			
	F3-6	ND												
	E3-6	ND							JB		2/28/12			
B	H5-6	ND												
	G5-6	ND												
	F5-6	ND												
	E5-6	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
TEM Asbeatoa Structure Coont

Laboratory name:	REI
Instmment	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20iX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Fitter Area (mm2)	
QA Type	

Client :	R+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	894
Date received by lab	2/27/12
Lab Job Number:	230511
Lab Sample Number:	8012.20

F-Factor Calculation (Indirect Preps Only):

Fraction of prtmary filter used	
Total Resuspension Volumo (ml)	
Volume Applied to secondary filter (ml)	

Analyzed bv	JB
Analysis date	2/28/12
Method (D=Direct, I=Indirect, IA=Indlrect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Mdnth Arialyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	F5-4	ND												
	E5-4	ND					Pmp A 80% intmf			3-5% debris				
	C5-4	ND					Pmp B 60% intmf			3-5% debris				
	B5-4	ND												
	A5-4	ND												
B	K3-3	ND								2/28/12				
	H3-3	ND												
	G3-3	ND												
	F3-3	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Reservoirs Environmental, Inc.
***TEM* Asbestos Structure Count**

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20)0 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R&R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	843
Date received by lab	2/27/12
Lab Job Number:	230511
Lab Sample Number:	849221

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/28/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class				1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM	Sketch/Comments	Sketch	Photo	EDS
A	G4-3	ND												
	F4-3	ND				Pump	A	50% amphibole			5% debris			
	E4-3	ND				Pump	B	~60% amphibole			5% debris			
	B4-3	ND												
	C4-3	ND												
B	K5-4	ND						2/28/12						
	H5-4	ND												
	G5-4	ND												
	F5-4	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

T:\Worksheet in TEM Data\...

Reservoirs Environmental, Inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX (N) S
Voltage (KV)	100 KV
Magnification	(20KX) 10KX
Grid opening area (mm2)	0.011
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Type	

Client :	R+R
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	889
Date received by lab	2/27/12
Lab Job Number:	23051
Lab Sample Number:	869222

F-Factor Calculation (Indirect Preps Only):

Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	2/28/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure Type	No. of Structures		Dimensions		Identification	Mineral Class			Sketch/Comments	1 = yes, blank = no		
			Primary	Total	Length	Width		Amphibole	C	NAM		Sketch	Photo	EDS
A	L5-1	ND												
	K5-1	ND					Prep A	80% bi-mat		3-5% debris				
	H5-1	ND					Prep B	90% bi-mat		3-5% debris				
	G5-1	ND												
	F5-1	ND						JB 2/28/12						
B	H5-1	ND												
	G5-1	ND												
	F5-1	ND												
	E5-1	ND												

LA = Libby-type amphibole OA = Other (non-Libby type) amphibole C = Chrysotile NAM = Non-asbestos material

Analytical Procedures – AHERA

Transmission electron microscopy/energy dispersive X-ray spectrometry/selected area electron diffraction (TEM/EDX/SAED) was employed in the analysis of the samples, which were collected on 25 mm mixed cellulose ester air filters. A portion of each filter was collapsed with acetone and etched in a plasma asher. The etched filter was then coated with a thin layer of carbon in a carbon side down. The sample was then placed inside a condensation washer and treated with acetone to remove the filter matrix and expose any inert material.

For each sample, enough grid openings on a 200 mesh TEM grid are analyzed to ensure an analytical sensitivity of at least 0.005 structures/cc. A minimum of four grid openings from two preparations are analyzed for each sample. The grid openings are searched for fibrous structures which, if present are analyzed by SAED and/or EDX (elemental analysis). The AHERA protocol requires SAED confirmation of enough chrysotile asbestos structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures). Both SAED and EDX confirmation are required of enough amphibole structures on each sample to cause the sample to exceed 70 structures/mm^2 (usually 4 or 5 structures) per sample. Either SAED or EDX is required for the remaining asbestos structures of either type. The morphology of each structure is determined and the length and the diameter of any asbestos structures are recorded. Asbestos fibers, bundles, cluster and matrices were identified and recorded. The asbestos structures have been defined in AHERA as follows:

Fiber:	is a structure having a minimum length greater than or equal to 0.5 micron with an aspect ratio of 5:1 or greater with substantially parallel sides.
Bundle:	is a structure composed of three or more fibers in parallel arrangement, with each fiber closer than the diameter of one fiber.
Cluster:	is a structure with fibers in random arrangements such that all fibers are intermixed and no single fiber is isolated from the group.
Matrix:	is a fiber or fibers with one end free and the other end embedded or hidden by a particulate. The exposed fiber end must meet the fiber definifion given above.

If more than 50 asbestos structures are identified and confirmed on a sample, AHERA analysis may be terminated after completion of the grid opening, which contains the 50^{th} structure. AHERA protocol requires the laboratory to reject any clearance sample which contains in excess of 25% total particulate loading or which appears to be uneyenly loaded.

The AHERA protocol includes specific sampling requirements, including minimum numbers of samples and minimum air volumes. Specifically, the 70 structures/mm^2 clearance criteria is only allowed for sets five inside samples (collected in a group of 13 samples including: five outsides and three blanks) with volumes greater than 1200 liters (40 CFR Part 763, page 41894). Deviation from the AHERA sampling protocol may affect the validity of the analytical results. Analysis of samples collected by non-protocol methods are not accredited by NVLAP

Equations Used for Calculations

$$\text{Area Analyzed, } mm^2 = \#\text{ GO counted} \times \text{Average GO Area (mm)}$$

$$\text{Concentration, s/cc} = \frac{\#\text{ Asbestos Structures}}{\#\text{ GO Counted}} \times \frac{1}{\text{Volume (L)}} \times \frac{\text{Eff. Filter Area } (mm^2)}{\text{Average GO area } (mm^2)} \times \frac{1L}{1000cc}$$

$$\text{Filter loading, s/mm2} = \frac{\#\text{ Asbestos structures}}{\text{Area Analyzed } (mm^2)}$$

GO = TEM grid opening

File: Shared on server T/Offfonns.sg/AHERA Procedures
Revised: 02/27/02